

Montgomery County Public Schools Facilities Guide

DIVISION 16 – ELECTRICAL

SECTION 16170 CIRCUIT AND MOTOR DISCONNECTS

PART 1 – GENERAL

A. Disconnect switches:

1. All exterior and kitchen disconnects and combination starters shall be in NEMA 4X enclosures.
2. Boiler Room:
 - a. Provide a non-fused disconnect lockable in the off position for each boiler.
3. See Standard Detail for disconnects located on roof. See Standard Detail E-11.0 on the following pages.
4. Manufacturers: Square D Company, Eaton/Cutler-Hammer, Siemens, General Electric

DISCONNECT MOUNTING ON ROOF	DESIGNED BY: <u>LRM</u>	REV <u>041709</u>
	APPROVED BY: <u>MCPS</u>	STANDARD NO.
	DATE <u>02/06/09</u>	E-11.0

