

Montgomery County Public Schools Facilities Guide

DIVISION 16 – ELECTRICAL

**SECTION 16460 TRANSFORMERS**

**PART 1 – GENERAL**

- A. Dry-type, general-purpose transformers shall be Energy Efficient type in compliance with NEMA TP 1.
- B. Transformers coils: Continuous copper windings without splices except for taps.
- C. Provide K-13 transformers for computer power.
- D. Manufacturers: Square D, Eaton/Cutler-Hammer, Sola/Hevi-Duty Electric, General Electric