

Updated Analysis of Drinking Water Samples Montgomery County Public Schools

The following are the current results of the continuing analysis of water taken from all sources within a sample of public schools in Montgomery County. Highest level results are being retested to ensure validity. The high samples include remote sites (such as sink faucets) and not designated drinking water sources.

The water samples at individual schools were collected by school system staff, using protocols approved by the Montgomery County Health Department, as recommended by the Environmental Protection Agency (EPA). The samples were analyzed at the lab facilities of Washington Suburban Sanitary Commission (WSSC). The action level standard is a water sample in which the level of lead content is greater than 20 parts per billion (ppb).

Available Results for Schools Tested¹

School	Total# ²	#High PPB ³	%High PPB ⁴	Highest PPB ⁵	Lowest PPB ⁶	Median PPB ⁷
1. Ashburton Elementary*	102	6	6%	494	0.2	1.5
2. Beall Elementary*	92	3	3%	86.6	0	1.0
3. Bel Pre Elementary	88	23	26%	8014.0	0.2	7.2
4. Bells Mill Elementary*	87	8	9%	255.4	0.2	5.0
5. Belmont Elementary*	82	9	11%	95.2	0.2	5.6
6. Beverly Farms Elementary*	95	13	14%	1718	0	5.9
7. Broad Acres Elementary	126	19	15%	1126	0	4.9
8. Cabin John Middle	71	7	10%	237.9	0.3	2.6
9. Candlewood Elementary*	85	18	21%	452.8	0.2	6.5
10. Cannon Road Elementary*	67	23	34%	838.2	0.2	12
11. Carderock Springs Elementary*	55	7	13%	186.5	0	5.5
12. Carl Sandburg Learning Center*	46	6	13%	804.3	0.3	4.1
13. Cashell Elementary*	61	10	16%	151.8	0.1	4.35
14. Clopper Mill Elementary*	97	35	36%	10374	0.2	11.6
15. Cloverly Elementary*	103	19	13%	691.2	0.2	5.6
16. Cold Spring Elementary*	81	27	29%	1016	0.5	11
17. College Gardens Elementary*	72	9	13%	70.2	0.1	3.7

School	Total# ²	#High PPB ³	%High PPB ⁴	Highest PPB ⁵	Lowest PPB ⁶	Median PPB ⁷
18. Cresthaven Elementary*	75	10	13%	155.1	0	4.5
19. Damascus Elementary*	89	24	25%	452.4	0.3	9.0
20. Darnestown Elementary*	70	23	30%	1584.5	0	11
21. East Silver Spring Elementary	86	24	28%	1085	0.3	9.1
22. Farquhar Middle*	181	43	24%	874.7	0.5	5.7
23. Fields Road Elementary*	73	12	16%	1390	0.1	5.8
24. Flower Hill Elementary	95	14	15%	145.5	0	4.6
25. Fox Chapel Elementary	93	2	2%	194.2	0.3	4.0
26. Gaithersburg Elementary	93	21	23%	109.3	0.2	10.0
27. Gaithersburg High	143	29	20%	7584	0.1	5.3
28. Garrett Park Elementary	63	13	21%	173.2	0.2	5.6
29. Georgian Forest Elementary*	79	1	1%	40.3	0	0.2
30. Glen Haven Elementary (Grosvenor)	67	17	25%	320.6	0.2	10.4
31. Glenallan Elementary*	78	15	19%	2390.0	0.2	6.8
32. Greencastle Elementary*	118	9	8%	894.5	0.1	2.7
33. Greenwood Elementary*	89	6	7%	135	0	3.5
34. Harmony Hills Elementary	83	1	1%	34	0	0.3
35. Kemp Mill Elementary*	125	1	1%	46.0	0	0.6
36. Lake Seneca Elementary	99	31	31%	500.4	0.1	11.9
37. Luxmanor Elementary*	62	13	21%	1632	0.1	4.1
38. Maryvale Elementary	76	9	12%	207.3	0.3	4.6
39. Montgomery Knolls Elementary	74	6	8%	218.5	0	3.2
40. New Hampshire Estates Elem.	103	8	8%	1205	0.2	1.7
41. Oak View Elementary	68	19	28%	496.6	0.1	16.9
42. Poolesville Elementary	105	16	15%	205.3	0.5	9.5
43. Rock Creek Forest Elementary*	90	14	16%	980.2	0	5.1
44. Rock View Elementary*	112	1	1%	34.2	0	0.5
45. Rockwell Elementary*	131	16	12%	307.7	0	3.5

School	Total# ²	#High PPB ³	%High PPB ⁴	Highest PPB ⁵	Lowest PPB ⁶	Median PPB ⁷
46. Rolling Terrace Elementary*	149	10	7%	33.1	0	2.5
47. Rosemary Hills Elementary	118	8	7%	665.3	0	1.9
48. Rosemont Elementary*	89	1	1%	28.4	0.1	1.2
49. Seven Locks Elementary*	55	18	33%	138.7	0.1	9.9
50. Somerset Elementary (at Radnor)*	64	27	42%	843.3	0.1	11.1
51. Southlake Elementary	75	13	17%	2423	1	7.6
52. Stedwick Elementary	103	10	10%	118.2	0.2	4.6
53. Stephen Knolls School	82	22	27%	1004.8	0.2	8.9
54. Stone Mill Elementary*	133	33	25%	536.8	0.1	2.9
55. Strathmore Elementary*	96	33	34%	4134.0	0.1	8.1
56. Summit Hall Elementary	86	10	12%	633.7	0.1	6.3
57. Takoma Park Elementary	84	9	11%	165.8	0.2	4.0
58. Thomas Edison HS of Technology*	85	24	28%	659.4	0.4	9.8
59. Thurgood Marshall Elementary*	130	17	13%	1152.0	0	2.1
60. Travilah Elementary*	75	6	4%	2694.2	0.3	3.3
61. Twinbrook Elementary	119	15	13%	1866	0.1	5.0
62. Viers Mill Elementary*	129	21	16%	589.6	0.1	3.1
63. Washington Grove Elementary	76	34	45%	1835	0.1	13.3
64. Wayside Elementary*	93	17	18%	2129	0	4
65. Weller Road Elementary	97	16	16%	1653.0	0.1	7.05
66. Wheaton High	152	22	14%	4134	0	3.6
67. Whetstone Elementary	116	13	11%	240.6	0.2	4.1
68. Woodlin Elementary*	94	9	10%	778.6	0	2.7

*Schools added to list on August 27, 2004.

¹ Updated August 27, 2004 and listed alphabetically by school

² Total#: Number of all water sources in the school.

³ #High PPB: Number of water sources with levels of lead above 20 parts per billion (ppb).

⁴ %High PPB: Percentage of water sources with levels of lead above 20 ppb.

⁵ Highest PPB: Single water source with highest level of lead, measured as ppb.

⁶ Lowest PPB: Single water source with lowest level of lead, measured as ppb.

⁷ Median PPB: The point below which 50% of the water sources fell in terms of measured ppb.