

**DESCRIPTION OF COLUMNS IN TABLE BELOW:**

Initial Testing Complete	sampling of all school drinking water sources
Fixtures needing Remediation	some water fixtures will be replaced (yes or no)
Remediation Plan	plan approved by MCHHS and MCDEP
Repairs in Progress	(self explanatory)
Post-Remediation Passivation and Testing	special flushing procedures for replaced fixtures to facilitate development of protective film
Done!*	All schools should continue once a day flushing (15 minutes for refrigerated water coolers, 1 minute for other drinking sources)

School	Initial Testing Complete	Fixtures needing remediation	Remediation Plan	Repairs in Progress	Post-Remediation Passivation and Testing	Done!*
A Mario Loiderman MS	newer school					
Albert Einsten HS						
Argyle MS		yes				
Ashburton ES		yes				
Bannockburn ES						
Beall ES		no	-----	-----		
Bel Pre ES		yes				
Bells Mill ES						
Belmont ES						
Benjamin Banneker MS						
Bethesda Chevy Chase HS		yes				
Bethesda ES		no	-----	-----		
Beverly Farms ES						
Bradley Hill ES						
Briggs Chaney MS						
Broad Acres ES						
Brooke Grove ES		no	-----	-----		
Brookhaven ES						
Brown Station ES						
Burning Tree ES						
Burnt Mills Road ES		yes				
Burtonsville ES		yes				
Cabin John MS						
Candlewood ES						
Cannon Road ES						
Capt James Daly ES		yes				
Carderock Springs ES		yes				
Carl Sandburg Learning Center						
Carver Educational Service Center						
Cashell ES		yes				
Cedar Grove ES		yes				
Chevy Chase ES		yes				

School	Initial Testing Complete	Fixtures needing remediation	Remediation Plan	Repairs in Progress	Post-Remediation Passivation and Testing	Done!*
Clarksburg ES		yes				
Clarksburg HS	newer school					
Clearspring ES						
Clopper Mill ES						
Cloverly ES						
Col. E. Brook Lee MS						
Col. Zadok Magruder HS						
Cold Spring ES						
College Gardens ES	under construction					
Concord						
Cresthaven ES		yes				
Damascus ES						
Damascus HS						
Darnestown ES		yes				
Diamond ES						
Dr. Charles Drew ES		yes				
Dr. Sally K. Ride ES		yes				
DuFief ES		yes				
Earle B. Wood MS		no	-----			
East Silver Spring ES				summer 07		
Eastern MS						
Emory Grove Center						
Fairland ES						
Fallsmead ES						
Farmland ES						
Fields Road ES						
Flower Hill ES						
Flower Valley ES		yes				
Forest Knolls ES						
Food Service Warehouse		no	-----			
Forest Oak MS		no	-----			
Fox Chapel ES						

School	Initial Testing Complete	Fixtures needing remediation	Remediation Plan	Repairs in Progress	Post-Remediation Passivation and Testing	Done!*
Francis Scott Key MS				to be demolished		
Gaithersburg ES						
Gaithersburg HS						
Gaithersburg MS						
Galway ES						
Garrett Park ES						
Georgian Forest ES		no	-----			
Germantown ES						
Glen Haven ES		yes				
Glenallan ES						
Goshen ES						
Great Seneca Creek ES	newer school					
Greencastle ES						
Greenwood ES						
Grosvenor Center						
Hadley Farms Alternative MS		no	-----			
Harmony Hills ES		no	-----			
Herbert Hoover MS						
Highland ES		yes				
Highland View ES		yes				
Jackson Road ES		yes				
James Hubert Blake HS						
John F. Kennedy HS						
John Poole MS		yes				
John T. Baker MS						
Jones Lane ES						
Judith A. Resnik ES		yes				
Julius West MS		yes				
Kemp Mill ES		no	-----			
Kensington Parkwood ES	newer school					
Kingsview MS						
Lake Seneca ES		yes				

School	Initial Testing Complete	Fixtures needing remediation	Remediation Plan	Repairs in Progress	Post-Remediation Passivation and Testing	Done!*
Lakelands Park MS		no	-----			
Lakewood ES		yes				
Lathrop E. Smith Environmental Educational Center						
Laytonsville ES	n/a - Well Water System - bottled drinking water					
Little Bennet ES	newer school					
Lois P. Rockwell ES						
Lucy Barnesley ES		no	-----			
Luxmanor ES						
Lynnbrook Center						
Mark Twain						
Martin Luther King MS						
Maryvale ES						
McKenney Hills Learning Center				summer 07		
Meadow Hall ES		yes				
Mill Creek Towne ES		yes				
Monocacy ES	n/a - Well Water System - bottled drinking water					
Montgomery Blair HS						
Montgomery Knolls ES		yes				
Montgomery Village MS						
Neelsville MS						
New Hampshire Estates ES						
Newport Mill MS						
North Bethesda MS		yes				
North Chevy Chase ES		yes				
Northwest HS						
Northwood HS				summer 07		
Oak View ES	newer school					
Oakland Terrace ES						
Olney ES		yes				
Paint Branch HS		yes				
Pine Crest ES						
Piney Branch ES		yes				

School	Initial Testing Complete	Fixtures needing remediation	Remediation Plan	Repairs in Progress	Post-Remediation Passivation and Testing	Done!*
Poolesville ES						
Poolesville HS						
Potomac ES						
Quince Orchard HS						
Rachel Carson ES		yes				
Radnor Center (Avalon School)						
Redland MS						
Richard Montgomery HS				to be demolished		
Ridgeview MS						
Ritchie Park ES						
Robert Frost MS						
Roberto Clemente MS						
Rockwell						
Rock Creek Forest ES		yes				
Rock Creek Valley ES		no				
Rock Terrace						
Rock View ES		yes				
Rockinghorse Road Center						
Rockville HS	newer school					
Rocky Hill MS	newer school					
Rolling Terrace ES						
Ronald McNair ES		yes				
Rosa M. Parks MS		yes				
Roscoe Nix ES		no				
Rosemary Hills ES		yes				
Rosemont ES		yes				
S. Christie McAuliffe ES		yes				
Sargent Shriver ES	newer school					
Seneca Valley HS	Filters tested and changed every 6 months					
Sequoyah ES		yes				
Seven Locks ES				summer 07		
Shady Grove MS						

School	Initial Testing Complete	Fixtures needing remediation	Remediation Plan	Repairs in Progress	Post-Remediation Passivation and Testing	Done!*
Sherwood ES						
Sherwood HS						
Silver Spring International MS						
Sligo Creek ES						
Sligo MS						
Somerset ES		no	-----			
South Lake ES		yes				
Spark M. Matsunaga ES						
Spring Mill Center						
Springbrook HS						
Stedwick ES						
Stephen Knolls School						
Stone Mill ES				summer 07		
Stonegate ES						
Strathmore ES		yes				
Strawberry Knoll ES		yes				
Summitt Hall ES						
Takoma Park ES						
Takoma Park MS						
Thomas Edison HS						
Thomas Pyle MS		yes				
Thomas S. Wootton HS						
Thurgood Marshall ES		yes				
Tilden Center/Parkland MS						
Tilden MS						
Travilah ES		no	-----			
Twinbrook ES						
Viers Mill ES		yes				
Walt Whitman HS						
Walter Johnson HS						
Washington Grove ES						
Waters Landing ES		yes				

School	Initial Testing Complete	Fixtures needing remediation	Remediation Plan	Repairs in Progress	Post-Remediation Passivation and Testing	Done!*
Watkins Mill ES	Yes					
Watkins Mill HS	Yes			Yes		
Wayside ES	Yes					
Weller Road ES	Yes					
Westbrook ES		Yes				
Westland MS		No				
Westover ES		Yes				
Wheaton HS	Yes			Yes		
Wheaton Woods ES	Yes					
Whetstone ES		Yes				
White Oak MS		Yes				
William M. Farquhar MS	Yes					
William Tyler Page ES		Yes				
Winston Churchill HS	Yes					
Wood Acres ES	Yes					
Woodfield ES	Yes					
Woodlin ES	Yes					
Wyngate ES		Yes				