

October 28, 2021


ERRATUM #2

**Request for Proposal 4361.3
Power Purchase Agreement for Electricity from Solar Photovoltaic Systems**

Please note the following standard that MCPS follows regarding the existing parking lot lights in reference to the above-mentioned Request for Proposal:

APPLICATIONS	AVERAGE ILLUMINATION LEVEL (FC)	MAX LIGHTING POWER DENSITIES (WATTS/SQUARE FOOT)	OTHER CONSIDERATIONS
Parking Lot	1.0	0.15	Use 100% cut-off fixtures on 20' poles. Ensure uniformity ratios do not exceed 20:1
Driveway		0.2	
Building Security	-	0.3 for each illuminated wall	
Entrance Canopy		1.25	
Main Building Entries	-	30W/linear foot of door width	
Other Building Entries	-	20W/linear foot of door width	
Loading Dock	5	20W/linear foot of door width.95	

All other terms and conditions remain the same.


 Angela McIntosh-Davis, CPPB, Team Leader
 Procurement Unit

AMD

Please indicate your receipt of this notice by signing below and return with your bid or under separate cover.

Accepted: _____
Name and Title

Name of Company: _____