

August 8, 2020

AMENDMENT #1 - REVISED

Invitation for Bid # 9461.1, Air Handler Unit Replacement at West Farm Depot

The above referenced Invitation for Bid is hereby modified to reflect the following changes:

Under II DETAILED SPECIFICATIONS/SCOPE OF WORK

1. Remove Paragraph 13 and 14 and replace with the following:

Provide two proposals as follows:

Option 1:

Proposal using existing underground refrigerant lines after flushed, pressure tested and confirmed that the existing line sizes will accommodate the new split condenser system.

Option 2:

Proposal including installation of new support system above ground, new above ground refrigerant lines; lines should be sized accordingly for new system. Existing refrigerant lines should be abandoned and capped. This will be an Add/Deduct. If the existing lines are reused this price will be deducted from the contract.

2. Bid opening date Tuesday, August 11, 2020 at 2:00 P. M. is hereby extended to **Tuesday August 18, 2020 at 1:00 P.M.**
3. All other terms and conditions remain the same.



Angela McIntosh-Davis, CPPB, Team Leader
Procurement Unit

AMD:lb

Attach:

Maryland's Largest School District

MONTGOMERY COUNTY PUBLIC SCHOOLS

Expanding Opportunity and Unleashing Potential

PROCUREMENT UNIT

Please indicate your receipt of this notice by signing below and return with your bid or under separate cover.

Received: _____
Name and Title

Name of Company: _____