

Montgomery County Public Schools Lead in Drinking Water Testing Report

Beverly Farms Elementary School
8501 Postoak Rd
Potomac, MD 20854

Report Date: March 31, 2026

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by Environmental Consulting Services, LLC is presented in the table below.

| | |
|---------------------------|------------|
| Sampling Date | 02/11/2026 |
| # of Outlets Tested | 59 |
| # of Outlets \geq 5 ppb | 0 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s):

A - Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

| Sampling Results-Beverly Farms Elementary School | | | | | |
|--|--------------------------------------|---|-----------------------|-----------|------------------|
| Outlet Barcode | Outlet Location | Outlet Type | Initial Results (ppb) | Pass/Fail | Status |
| LW04826 | In classroom 238 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| LW12927 | In hallway next to gym | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler | <1.0 | Pass | Testing Complete |
| LW12928 | In hallway across from classroom 255 | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler | <1.0 | Pass | Testing Complete |
| LW12929 | In hallway next to classroom 213 | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler | <1.0 | Pass | Testing Complete |
| LW14046 | In hallway next to 109 | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler | <1.0 | Pass | Testing Complete |
| M30388 | In health room 100A | Faucet, Cold | <1.0 | Pass | Testing Complete |
| M30389 | In health room 100A | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30391 | In health room 100A2 | Faucet, Cold | 2.1 | Pass | Testing Complete |
| M30393 | In office 100A3 by health | Faucet, Cold | 2.6 | Pass | Testing Complete |
| M30394 | In office 100A3 by health | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30396 | In work room 100C by admin | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M30399 | In music 117 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30403 | In art 121 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30409 | In classroom 123 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30411 | In classroom 112 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30414 | In classroom 127 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30420 | In classroom 116 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30422 | In classroom 129 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initial Results (ppb) | Pass/Fail | Status |
|----------------|------------------------|---|-----------------------|-----------|------------------|
| M30424 | In classroom 133 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30430 | In classroom 128 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30432 | In classroom 135 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30434 | In office 130 | Drinking Water Fountain | <1.0 | Pass | Testing Complete |
| M30437 | In classroom 139 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30440 | In classroom 141 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30445 | In hallway next to gym | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M30446 | In hallway next to gym | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M30449 | In classroom 145 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30450 | In kitchen 109B | Faucet, Cold | <1.0 | Pass | Testing Complete |
| M30451 | In kitchen 109B | Faucet, Cold | <1.0 | Pass | Testing Complete |
| M30452 | In kitchen 109B | Faucet, Cold | <1.0 | Pass | Testing Complete |
| M30454 | In kitchenette 109D | Faucet, Cold | <1.0 | Pass | Testing Complete |
| M30455 | In hallway next to 109 | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M30456 | In hallway next to 109 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M30465 | In office 101 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | 1.6 | Pass | Testing Complete |
| M30467 | In break room 200 | Faucet, Cold | <1.0 | Pass | Testing Complete |
| M30468 | In break room 200 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initial Results (ppb) | Pass/Fail | Status |
|----------------|----------------------------------|---|-----------------------|-----------|------------------|
| M30470 | In classroom 201 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30474 | In classroom 205 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30480 | In classroom 213 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30482 | In hallway next to classroom 213 | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M30483 | In hallway next to classroom 213 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M30484 | In classroom 222 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30489 | In classroom 226 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30490 | In classroom 221 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30492 | In classroom 228 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30496 | In classroom 227 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30499 | In office 238 | Drinking Water Fountain | <1.0 | Pass | Testing Complete |
| M30500 | In classroom 240 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | 1.4 | Pass | Testing Complete |
| M30503 | In classroom 229 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30505 | In classroom 246 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30506 | In classroom 233 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30508 | In classroom 248 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | 2.7 | Pass | Testing Complete |
| M30511 | In classroom 235 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30513 | In classroom 252 | Combination Sink - Fountain - Bubblers Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initial Results (ppb) | Pass/Fail | Status |
|-----------------------|--------------------------------------|--|------------------------------|------------------|------------------|
| M30514 | In classroom 239 | Combination Sink - Fountain - Bubbler Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30524 | In classroom 243 | Combination Sink - Fountain - Bubbler Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30525 | In classroom 247 | Combination Sink - Fountain - Bubbler Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30528 | In classroom 255 | Combination Sink - Fountain - Bubbler Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| M30531 | In hallway across from classroom 255 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Beverly Farms Elementary School
8501 Postoak Road
Potomac, MD 20854**

Report Date: June 26, 2023

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by Inspection Experts Inc is presented in the table below.

| | |
|---------------------------|---------|
| Sampling Date | 4/27/23 |
| # of Outlets Tested | 64 |
| # of Outlets \geq 5 ppb | 1 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the workplace and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s):

A- Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Beverly Farms ES

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|----------------|--------------------------|---|------------------------|-----------|------------------|
| LW04826 | In classroom 238 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30388 | In health room 100A | Nurses Office Sink | <1.0 | Pass | Testing Complete |
| M30389 | In health room 100A | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30391 | In health room 100A2 | Nurses Office Sink | 1.0 | Pass | Testing Complete |
| M30393 | In office 100A3 | Nurses Office Sink | <1.0 | Pass | Testing Complete |
| M30394 | In office 100A3 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30396 | In work room 100C | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30399 | In music 117 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30402 | In art 121 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30403 | In art 121 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30405 | In dual purpose room 104 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30409 | In classroom 123 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30411 | In classroom 112 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30414 | In classroom 127 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|-----------------------|------------------------|---|-------------------------------|------------------|------------------|
| M30420 | In classroom 116 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30422 | In classroom 129 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30424 | In classroom 133 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30430 | In classroom 128 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30432 | In classroom 135 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30434 | In office 130 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30437 | In classroom 139 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30440 | In classroom 141 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30445 | In hallway next to gym | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30446 | In hallway next to gym | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30449 | In classroom 145 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30450 | In kitchen 109B | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M30451 | In kitchen 109B | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M30452 | In kitchen 109B | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M30454 | In kitchenette 109D | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M30455 | In hallway 109 | Drinking Fountain | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|-----------------------|---------------------------|---|-------------------------------|------------------|------------------|
| M30456 | In hallway 109 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30465 | In office 101 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30467 | In break room 200 | Teachers Lounge Sink | <1.0 | Pass | Testing Complete |
| M30468 | In break room 200 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30470 | In classroom 201 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30474 | In classroom 205 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30480 | In classroom 213 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30482 | In hallway next to CR 213 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30483 | In hallway next to CR 213 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30484 | In classroom 222 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30487 | In classroom 217 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30489 | In classroom 226 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30490 | In classroom 221 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30492 | In classroom 228 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30495 | In classroom 223 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30496 | In classroom 227 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30500 | In classroom 240 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|-----------------------|---------------------------|---|-------------------------------|------------------|-------------------------|
| M30503 | In classroom 229 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30505 | In classroom 246 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30506 | In classroom 233 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30508 | In classroom 248 | Classroom Combination Drinking Fountain | 8.7 | Fail | Remediation Action Plan |
| M30511 | In classroom 235 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30513 | In classroom 252 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30514 | In classroom 239 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30524 | In classroom 243 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30525 | In classroom 247 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30528 | In classroom 255 | Classroom Combination Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30530 | In hallway 255 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30531 | In hallway 255 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30445-BF | In hallway next to gym | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30455-BF | In hallway 109 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30482-BF | In hallway next to CR 213 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M30530-BF | In hallway 255 | Drinking Fountain | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|-----------------------|------------------------|----------------------|-------------------------------|------------------|------------------|
| M30499 | In office 238 | Teachers Lounge Sink | <1.0 | Pass | Testing Complete |

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Beverly Farms Elementary School
8501 Postoak Road
Potomac, MD 20854**

Report Date: April 1st, 2020

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

| | |
|---------------------------|-----------|
| Sampling Date | 3/10/2020 |
| # of Outlets Tested | 102 |
| # of Outlets \geq 5 ppb | 0 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Beverly Farms ES

| Fixture Barcode | Fixture Location | Fixture Type | Initial Results (ppb) | Pass/Fail | Follow up Results (ppb) | Status |
|-----------------|---|---|-----------------------|-----------|-------------------------|------------------|
| LW04826 | In classroom 238 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30388 | In health room 100A | Nurses Office Sink | <1 | Pass | N/A | Testing Complete |
| M30389 | In health room 100A | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30391 | In health room 100A2 by health ie. in health | Nurses Office Sink | 1.3 | Pass | N/A | Testing Complete |
| M30393 | In office 100A3 by health ie. inside health | Nurses Office Sink | <1 | Pass | N/A | Testing Complete |
| M30394 | In office 100A3 by health ie. inside health | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30395 | In work room 100C by admin ie. inside admin | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30396 | In work room 100C by admin ie. inside admin | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30399 | In music 117 by music | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30400 | In music 117 by music | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30402 | In art 121 by art | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30403 | In art 121 by art | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30405 | In dual purpose room 104 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30406 | In dual purpose room 104 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30408 | In classroom 123 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30409 | In classroom 123 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30411 | In classroom 112 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30412 | In classroom 112 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30414 | In classroom 127 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30415 | In classroom 127 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30417 | In work room 120 by media center ie. inside 120 IMC | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30419 | In classroom 116 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30420 | In classroom 116 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30421 | In classroom 129 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30422 | In classroom 129 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30424 | In classroom 133 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30425 | In classroom 133 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30427 | In classroom 124 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30428 | In classroom 124 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|--------|--|---|----|------|-----|------------------|
| M30429 | In classroom 128 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30430 | In classroom 128 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30431 | In classroom 135 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30432 | In classroom 135 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30433 | In classroom 130 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30434 | In office 130 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30436 | In classroom 139 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30437 | In classroom 139 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30439 | In classroom 141 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30440 | In classroom 141 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30445 | In hallway next to gym | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30446 | In hallway next to gym | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30448 | In classroom 145 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30449 | In classroom 145 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30450 | In kitchen 109B by kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M30451 | In kitchen 109B by kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M30452 | In kitchen 109B by kitchen ie. inside kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M30454 | In kitchenette 109D by all purpose room ie. inside APR | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M30455 | In hallway 109 next to 109 APR | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30456 | In hallway 109 next to 109 APR | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30457 | In classroom 105 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30465 | In office 101 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30466 | In office 101 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30467 | In break room 200 | Teachers Lounge Sink | <1 | Pass | N/A | Testing Complete |
| M30468 | In break room 200 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30469 | In classroom 201 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30470 | In classroom 201 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30474 | In classroom 205 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30475 | In classroom 205 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30480 | In classroom 213 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30481 | In classroom 213 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30482 | In hallway next to CR 213 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|--------|---------------------------|---|----|------|-----|------------------|
| M30483 | In hallway next to CR 213 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30484 | In classroom 222 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30485 | In classroom 222 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30486 | In classroom 217 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30487 | In classroom 217 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30488 | In classroom 226 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30489 | In classroom 226 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30490 | In classroom 221 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30491 | In classroom 221 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30492 | In classroom 228 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30493 | In classroom 228 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30494 | In classroom 223 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30495 | In classroom 223 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30496 | In classroom 227 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30497 | In classroom 227 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30499 | In classroom 238 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30500 | In classroom 240 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30501 | In classroom 240 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30502 | In classroom 229 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30503 | In classroom 229 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30504 | In classroom 246 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30505 | In classroom 246 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30506 | In classroom 233 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30507 | In classroom 233 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30508 | In classroom 248 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30509 | In classroom 248 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30510 | In classroom 235 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30511 | In classroom 235 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30512 | In classroom 252 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30513 | In classroom 252 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30514 | In classroom 239 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30515 | In classroom 239 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|--------|---|---|----|------|-----|------------------|
| M30523 | In classroom 243 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30524 | In classroom 243 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30525 | In classroom 247 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30526 | In classroom 247 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30528 | In classroom 255 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30529 | In classroom 255 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M30530 | In hallway 255 across from CR 255 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30531 | In hallway 255 across from CR 255 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M30535 | In kitchenette 109D by all purpose room ie. inside APR | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |



Montgomery County Public Schools Lead in Drinking Water Testing 2018

Executive Summary:

Beverly Farms Elementary School

8501 Post oak Road

Potomac, Maryland 20854

| | |
|-----------------------------|-----------|
| Date of Test Report: | 3/30/2018 |
| Round of Testing: | Initial |
| # of Outlets Tested: | 106 |
| # of Outlets ≥ 20 ppb: | 0 |
| Low Value (ppb): | <1.0 |
| High Value (ppb): | 3.7 |

Project Status:

Initial testing complete: All results less than 20 ppb.



3/30/2018

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Drinking Water Testing

KCI Job #1214634186

Location: Beverly Farms Elementary School

8501 Postoak Road
Potomac, Maryland 20854

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of Initial lead in water testing at Beverly Farms Elementary School, located at 8501 Postoak Road in Potomac, Maryland 20854.

SCOPE OF SERVICES

KCI conducted lead in water testing at Beverly Farms Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

KCI visited the site on 3/7/2018 and 3/8/2018 to collect samples from 106 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water - Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

There are no results of the lead in water analysis at or above 20 parts per billion (ppb). The lead in water sample results for sample collection date 3/8/2018 are shown in Attachment A.

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM

Attachment:

A- Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: KCI Technologies, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Sample Results for Beverly Farms Elementary School

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB*) | Pass/Fail | Status |
|------------|--------|------------------------|----------------|------------------|----------------|-----------|------------------|
| LW04826 | 238 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30388 | 100A | Health Room | | Faucet | <1.0 | Pass | Testing Complete |
| M30389 | 100A | Health Room | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30391 | 100A2 | Health Room Health | in Health | Faucet | 1.7 | Pass | Testing Complete |
| M30392 | 100A2 | Health Room Health | inside Health | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30393 | 100A3 | Office Health | inside Health | Faucet | 1.2 | Pass | Testing Complete |
| M30394 | 100A3 | Office Health | inside Health | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30395 | 100C | Work Room Admin | inside Admin | Faucet | <1.0 | Pass | Testing Complete |
| M30396 | 100C | Work Room Admin | inside Admin | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30399 | 117 | Music | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30400 | 117 | Music | | Faucet | <1.0 | Pass | Testing Complete |
| M30401 | 121 | Art | | Faucet | <1.0 | Pass | Testing Complete |
| M30402 | 121 | Art | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30403 | 121 | Art | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30404 | 121 | Art | | Faucet | <1.0 | Pass | Testing Complete |
| M30405 | 104 | Dual Purpose Room | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30406 | 104 | Dual Purpose Room | | Faucet | <1.0 | Pass | Testing Complete |
| M30408 | 123 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30409 | 123 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30411 | 112 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30412 | 112 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30414 | 127 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30415 | 127 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30417 | 120 | Work Room Media Center | inside 120 IMC | Faucet | <1.0 | Pass | Testing Complete |
| M30418 | 120 | Work Room Media Center | inside 120 IMC | Bubbler - Indoor | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB*) | Pass/Fail | Status |
|------------|--------|------------------------------|-----------------|------------------|----------------|-----------|------------------|
| M30419 | 116 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30420 | 116 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30421 | 129 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30422 | 129 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30424 | 133 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30425 | 133 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30427 | 124 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30428 | 124 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30429 | 128 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30430 | 128 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30431 | 135 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30432 | 135 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30433 | 130 | Classroom | | Faucet | 3.7 | Pass | Testing Complete |
| M30434 | 130 | Office | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30436 | 139 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30437 | 139 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30439 | 141 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30440 | 141 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30445 | | Hallway | Next to Gym | Cooler | <1.0 | Pass | Testing Complete |
| M30446 | | Hallway | Next to Gym | Cooler | <1.0 | Pass | Testing Complete |
| M30448 | 145 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30449 | 145 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30450 | 109B | Kitchen Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| M30451 | 109B | Kitchen Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| M30452 | 109B | Kitchen Kitchen | inside Kitchen | Faucet | <1.0 | Pass | Testing Complete |
| M30454 | 109D | Kitchenette All Purpose Room | inside APR | Faucet | <1.0 | Pass | Testing Complete |
| M30455 | 109 | Hallway | Next to 109 APR | Cooler | <1.0 | Pass | Testing Complete |
| M30456 | 109 | Hallway | Next to 109 APR | Cooler | <1.0 | Pass | Testing Complete |
| M30457 | 105 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB*) | Pass/Fail | Status |
|------------|--------|------------|----------------|------------------|----------------|-----------|------------------|
| M30465 | 101 | Office | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30466 | 101 | Office | | Faucet | 1.3 | Pass | Testing Complete |
| M30467 | 200 | Break Room | | Faucet | <1.0 | Pass | Testing Complete |
| M30468 | 200 | Break Room | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30469 | 201 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30470 | 201 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30474 | 205 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30475 | 205 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30480 | 213 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30481 | 213 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30482 | | Hallway | Next to CR 213 | Cooler | <1.0 | Pass | Testing Complete |
| M30483 | | Hallway | Next to CR 213 | Cooler | <1.0 | Pass | Testing Complete |
| M30484 | 222 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30485 | 222 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30486 | 217 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30487 | 217 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30488 | 226 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30489 | 226 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30490 | 221 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30491 | 221 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30492 | 228 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30493 | 228 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30494 | 223 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30495 | 223 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30496 | 227 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30497 | 227 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30499 | 238 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30500 | 240 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30501 | 240 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB*) | Pass/Fail | Status |
|------------|--------|------------------------------|--------------------|------------------|----------------|-----------|------------------|
| M30502 | 229 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30503 | 229 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30504 | 246 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30505 | 246 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30506 | 233 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30507 | 233 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30508 | 248 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30509 | 248 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30510 | 235 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30511 | 235 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30512 | 252 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30513 | 252 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30514 | 239 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30515 | 239 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30523 | 243 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30524 | 243 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30525 | 247 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30526 | 247 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30528 | 255 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M30529 | 255 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M30530 | 255 | Hallway | Across from CR 255 | Cooler | <1.0 | Pass | Testing Complete |
| M30531 | 255 | Hallway | Across from CR 255 | Cooler | <1.0 | Pass | Testing Complete |
| M30535 | 109D | Kitchenette All Purpose Room | inside APR | Bubbler - Indoor | <1.0 | Pass | Testing Complete |

*PPB = parts per billion