



MONTGOMERY COUNTY PUBLIC SCHOOLS DRINKING WATER TESTING 2018

May 25, 2018

Executive Summary:
Quince Orchard High School
15800 Quince Orchard Road
Gaithersburg, MD 20878

| | |
|--|--------------------------|
| Round of Testing: | Initial |
| # of Outlets Tested: | 62 |
| # of Outlets \geq 20 ppb: | 1 |
| Low Value (ppb): | < 1.0 |
| High Value (ppb): | 29.1 |
| Follow-Up Testing Required (Samples \geq 20 ppb): | Training Room (29.1 ppb) |

| | |
|----------------------|-------------------------|
| Round of Testing: | Follow-Up – 30 sec draw |
| # of Outlets Tested: | 1 |

Project Status
Testing Complete: Remediation Plan

Training Room– Replace fixture (M35165), in addition to supply line and valve located under sink



May 25, 2018

Mr. Brian Mullikin
Environmental Team Leader
Montgomery County Public Schools
8301 Turkey Thicket Drive
Building A, First Floor
Gaithersburg, Maryland 20879

Re: Lead in Water Testing Service

Location: Quince Orchard High School
15800 Quince Orchard Road
Gaithersburg, MD 20878

Dear Mr. Mullikin:

Professional Services Industries (PSI), Inc. is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of initial lead in water testing at Quince Orchard High School, located at 15800 Quince Orchard Road in Gaithersburg, MD 20878.

Scope of Services:

PSI conducted lead in water testing at Quince Orchard High School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

PSI visited the site on 4/09/18 and 4/10/18 to collect samples from 62 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water—Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07. One 30 second follow-up sample was collected on 5/8/18.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

Results:

There was one result of the initial lead in water analysis at or above 20 parts per billion (ppb) and subsequent follow up 30 second results are highlighted in the summary table below:



| Barcode ID | Sample Location | Date Collected | Initial Sample Result (ppb) | Date Collected | 30 Second Follow Up Sample Result (ppb) |
|------------|-----------------|----------------|-----------------------------|----------------|---|
| M35165 | Training Room | 4/10/18 | 29.1 | 5/8/18 | <1.0 |

The initial lead in water sample results (4/10/18) and 30 second follow up results (5/8/18) are shown in Attachment A.

Discussion:

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children’s brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990’s could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,

PROFESSIONAL SERVICE INDUSTRIES, INC.

Nand Kaushik, P.E.
Department Manager, Environmental Services
Nand.Kaushik@psiusa.com

- Attachments:
- A – Floor Plan with Test Locations
 - B – Lead in Water Test Summary Table
 - C – Laboratory Analytical Results and Chain of Custody

ATTACHMENT A

Quince Orchard HS Water Test Summary Table

Contractor: Professional Services Industries, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Initial Sample Results for Quince Orchard High School (4/10/18)

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results | Pass/Fail | Status |
|------------|--------|-------------------------------------|--------------------------|------------------|---------|-----------|------------------|
| LW08586 | | Hallway | Next to 308 | Cooler | <1.0 | Pass | Testing Complete |
| LW08587 | | Hallway | Next to 308 | Cooler | <1.0 | Pass | Testing Complete |
| LW08588 | 308 | Break Room | | Faucet | <1.0 | Pass | Testing Complete |
| LW08589 | | Hallway | Next to 323b | Cooler | <1.0 | Pass | Testing Complete |
| LW08590 | | Hallway | Across from 338 | Cooler | <1.0 | Pass | Testing Complete |
| LW08591 | | Hallway | Across from 338 | Cooler | <1.0 | Pass | Testing Complete |
| LW08592 | | Hallway | Across from Media Center | Cooler | <1.0 | Pass | Testing Complete |
| LW08593 | | Kitchen | | Faucet | 1.0 | Pass | Testing Complete |
| LW08594 | | Kitchen | | Faucet | 3.7 | Pass | Testing Complete |
| LW08595 | | Kitchen | | Icemaker | <1.0 | Pass | Testing Complete |
| LW08596 | 133 | Computer Lab | | Faucet | 1.1 | Pass | Testing Complete |
| LW08606 | | Training Room Locker Room - Boys | | Icemaker | <1.0 | Pass | Testing Complete |
| LW08607 | | Locker Room - Girls | | Cooler | <1.0 | Pass | Testing Complete |
| LW08608 | | Hallway | Across from 119B | Cooler | <1.0 | Pass | Testing Complete |
| LW08609 | 119G | Computer Lab | | Faucet | 1.7 | Pass | Testing Complete |
| LW08610 | | Hallway | Next to 126 | Cooler | <1.0 | Pass | Testing Complete |
| LW08611 | | Hallway | Next to 126 | Cooler | <1.0 | Pass | Testing Complete |
| LW08612 | 124A | Music | | Faucet | <1.0 | Pass | Testing Complete |
| LW08613 | 124A | Music | | Faucet | <1.0 | Pass | Testing Complete |
| LW08614 | 124A | Music | | Faucet | 2.7 | Pass | Testing Complete |
| LW08615 | 121 | Child Development | | Faucet | 1.0 | Pass | Testing Complete |
| LW08616 | 121 | Child Development | | Faucet | 1.4 | Pass | Testing Complete |
| LW08617 | 121 | Child Development | | Faucet | 2.6 | Pass | Testing Complete |
| LW08618 | 121 | Child Development | | Bubbler - Indoor | 2.2 | Pass | Testing Complete |
| LW08710 | | Hallway | Across from Media Center | Cooler | <1.0 | Pass | Testing Complete |
| LW08711 | 251 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| LW08712 | 254 | Health Room | | Faucet | 1.3 | Pass | Testing Complete |
| LW08713 | 259 | Concession | | Faucet | 4.4 | Pass | Testing Complete |
| LW08714 | 259 | Concession | | Faucet | 5.3 | Pass | Testing Complete |
| LW08715 | 259 | Concession | | Icemaker | <1.0 | Pass | Testing Complete |
| LW08716 | | Hallway | Next to Restroom | Cooler | <1.0 | Pass | Testing Complete |
| LW08717 | | Hallway | Next to Restroom | Cooler | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results | Pass/Fail | Status |
|------------|--------|-----------------------|-------------------------|----------------|---------|-----------|--------------------------|
| LW08718 | | Hallway | Next to Restroom | Cooler | <1.0 | Pass | Testing Complete |
| LW08719 | | Hallway | Across from Gym | Cooler | <1.0 | Pass | Testing Complete |
| LW08720 | | Hallway | Across from Gym | Cooler | <1.0 | Pass | Testing Complete |
| LW08721 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW08722 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW08944 | | Kitchen | | Faucet | 1.1 | Pass | Testing Complete |
| LW08945 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW08946 | | Kitchen | | Faucet | 3.0 | Pass | Testing Complete |
| LW08947 | | Kitchen | | Faucet | 3.6 | Pass | Testing Complete |
| LW08948 | | Kitchen | | Faucet | 4.7 | Pass | Testing Complete |
| LW08949 | | Hallway | Across from Kitchen | Cooler | <1.0 | Pass | Testing Complete |
| LW08950 | | Hallway | Across from Kitchen | Cooler | <1.0 | Pass | Testing Complete |
| LW08951 | | Hallway | Across from 288B | Cooler | <1.0 | Pass | Testing Complete |
| LW08952 | | Hallway | Across from 152 | Cooler | <1.0 | Pass | Testing Complete |
| LW08953 | | Locker Room - Boys | | Cooler | <1.0 | Pass | Testing Complete |
| LW08954 | | Hallway | Next to Electrical Room | Cooler | <1.0 | Pass | Testing Complete |
| LW08956 | | Hallway | Next to Electrical Room | Cooler | <1.0 | Pass | Testing Complete |
| M05969 | 119E | Classroom | | Faucet | 3.3 | Pass | Testing Complete |
| M05970 | 153A | Music Storage | | Faucet | 6.8 | Pass | Testing Complete |
| M35134 | 120 | Classroom | | Faucet | 4.7 | Pass | Testing Complete |
| M35165 | | Training Room | | Faucet | 29.1 | Fail | Follow-Up Testing Needed |
| M35167 | | Training Room | | Faucet | 17.7 | Pass | Testing Complete |
| M35181 | 134 D | Dressing Room - Girls | | Faucet | 3.3 | Pass | Testing Complete |
| M35182 | 134D | Dressing Room - Girls | | Faucet | 3.2 | Pass | Testing Complete |
| M35217 | 200D | Work Room Admin | | Faucet | 1.2 | Pass | Testing Complete |
| M36133 | | Hallway | Across from 119B | Cooler | <1.0 | Pass | Testing Complete |
| M46192 | | Hallway | Across IMC | Cooler | <1.0 | Pass | Testing Complete |
| M46199 | 245 | Media Center | | Faucet | <1.0 | Pass | Testing Complete |
| M46204 | 231 | Office | | Faucet | <1.0 | Pass | Testing Complete |
| M46205 | | Hallway | Across From 288B | Cooler | <1.0 | Pass | Testing Complete |

*ppb = parts per billion

Contractor: Professional Services Industries, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Follow Up Sample Results for Quince Orchard High School (5/8/18)

| Barcode ID | Room Number | Location | Equipment Type | Initial draw (2 nd) (PPB) | 30 Second Draw (PPB) | Status |
|------------|-------------|---------------|----------------|---------------------------------------|----------------------|---|
| M35165 | | Training Room | Faucet | 7.3 | <1.0 | Remediation required – replace fixture, in addition to supply line and valve located under sink |

*ppb = parts per billion

Note: Fixture(s) with elevated test results were immediately removed from service. Subsequent 2nd round testing was performed on these fixture(s) for further diagnostics for remediation. Because the fixture was shut off after the first test, the subsequent test results may not be representative of an in-use fixture because of stagnant water in the supply line and the operation of shut off valves prior to the tests. All fixtures with elevated test results are to be remediated. After remediation, post remediation testing will be conducted before the fixture is returned to service.