



Montgomery County Public Schools Lead in Drinking Water Testing 2018

April 30, 2018

Executive Summary:

Briggs Chaney Middle School

1901 Rainbow Drive

Silver Spring, Maryland 20905

Round of Testing:	Initial
# of Outlets Tested:	29
# of Outlets \geq 20 ppb:	0
Low Value (ppb):	<1.0
High Value (ppb):	6.9

Project Status:

Initial testing complete: All results less than 20 ppb.



April 30, 2018

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Drinking Water Testing

KCI Job #1214634191

Location: Briggs Chaney Middle School

1901 Rainbow Drive
Silver Spring, Maryland 20905

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of Initial lead in water testing at Briggs Chaney Middle School, located at 1901 Rainbow Drive in Silver Spring, Maryland 20905.

SCOPE OF SERVICES

KCI conducted lead in water testing at Briggs Chaney Middle School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

KCI visited the site on 4/3/2018 and 4/4/2018 to collect samples from 29 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water - Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

There are no results of the lead in water analysis at or above 20 parts per billion (ppb). The lead in water sample results for sample collection date 4/4/2018 are shown in Attachment A.

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM

Attachment:

A- Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: KCI Technologies, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Sample Results for Briggs Chaney Middle School

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
G75746		Kitchen		Icemaker	<1.0	Pass	Testing Complete
LW04446		Team Room		Faucet	2.7	Pass	Testing Complete
LW04447	33	Hallway	Across From	Cooler	<1.0	Pass	Testing Complete
LW04448		Locker Room - Girls		Cooler	<1.0	Pass	Testing Complete
LW04449		Health Room		Faucet	1.6	Pass	Testing Complete
LW04450	16	Classroom		Faucet	<1.0	Pass	Testing Complete
LW05192	SS	Student Services		Faucet	2.8	Pass	Testing Complete
LW05193		Kitchen		Faucet	4.3	Pass	Testing Complete
LW05194		Kitchen		Faucet	4.9	Pass	Testing Complete
LW05195		Kitchen		Faucet	3.2	Pass	Testing Complete
LW05196		Kitchen		Faucet	4.0	Pass	Testing Complete
LW05197		Kitchen		Faucet	5.6	Pass	Testing Complete
LW05198		Kitchen		Faucet	2.5	Pass	Testing Complete
LW05199		Cafeteria		Cooler	<1.0	Pass	Testing Complete
LW05200		Locker Room - Boys		Cooler	<1.0	Pass	Testing Complete
LW05201		Hallway Cafeteria	Across From	Cooler	<1.0	Pass	Testing Complete
LW05202	6	Hallway	Across From	Cooler	<1.0	Pass	Testing Complete
M36867	8A	Team Rm		Faucet	6.9	Pass	Testing Complete
M36882		Hallway	Across from CR 37	Cooler	<1.0	Pass	Testing Complete
M36884		Team Room		Faucet	4.9	Pass	Testing Complete
M36903		Hallway	Across from CR 27	Cooler	<1.0	Pass	Testing Complete
M36908		Hallway	Across from 23	Cooler	<1.0	Pass	Testing Complete

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
M36909	7A	Work Room		Faucet	4.7	Pass	Testing Complete
M40042	6A	Team Rm		Faucet	2.1	Pass	Testing Complete
M40058		Kitchen		Faucet	1.2	Pass	Testing Complete
M40070		Kitchen		Faucet	3.5	Pass	Testing Complete
M45987		Break Room		Faucet	3.3	Pass	Testing Complete
M46016		Hallway	Next Computer 6	Cooler	<1.0	Pass	Testing Complete
M46027	6B	Team Rm		Faucet	4.3	Pass	Testing Complete

*PPB = parts per billion