

Montgomery County Public Schools Lead in Drinking Water Testing Report

New Hampshire Estates Elementary School
8720 Carroll Avenue
Silver Spring, MD 20903

Report Date: August 13th, 2020

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

Sampling Date	2/21/2020
# of Outlets Tested	74
# of Outlets \geq 5 ppb	4

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. Due to the Stay-at-Home Order to combat the spread of COVID-19 (coronavirus), no follow-up samples were collected. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for New Hampshire Estates ES

Fixture Barcode	Fixture Location	Fixture Type	Initial Results (ppb)	Pass/Fail	Follow up Results (ppb)	Status
LW00543	In hallway next to gym	Drinking Fountain	<1	Pass	N/A	Testing complete
LW00544	In cafeteria right of kitchen	Drinking Fountain	<1	Pass	N/A	Testing complete
LW00545	In music 228	Classroom Combination Sink	1.2	Pass	N/A	Testing complete
LW00546	In work room by media center	Classroom Sink	1.1	Pass	N/A	Testing complete
LW00547	In classroom 230	Classroom Combination Drinking Fountain	1.0	Pass	N/A	Testing complete
LW00552	In art 231	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00553	In art 231	Classroom Combination Drinking Fountain	1.0	Pass	N/A	Testing complete
LW00555	In work room by administration	Classroom Sink	<1	Pass	N/A	Testing complete
LW00556	In health room	Nurses Office Sink	<1	Pass	N/A	Testing complete
LW00557	In health room H-8	Nurses Office Sink	1.3	Pass	N/A	Testing complete
LW00558	In health room H-11	Nurses Office Sink	7.3	Fail	NC	Remediation Action Plan
LW00559	In health room H-9	Nurses Office Sink	16.3	Fail	NC	Remediation Action Plan
LW00560	In classroom 215	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00561	In classroom 251	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00562	In classroom 204	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00563	In classroom 204	Classroom Combination Drinking Fountain	4.9	Pass	N/A	Testing complete
LW00564	In classroom 216	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00565	In classroom 216	Classroom Combination Drinking Fountain	3.1	Pass	N/A	Testing complete
LW00566	In classroom 205	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00567	In classroom 205	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00568	In classroom 217	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00569	In classroom 217	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00570	In classroom 206	Classroom Combination Sink	1.1	Pass	N/A	Testing complete
LW00571	In classroom 206	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00572	In classroom 218	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00573	In classroom 218	Classroom Combination Drinking Fountain	6.5	Fail	NC	Remediation Action Plan

LW00574	In classroom 219	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00575	In classroom 219	Classroom Combination Drinking Fountain	1.3	Pass	N/A	Testing complete
LW00576	In office 209	Classroom Sink	1.7	Pass	N/A	Testing complete
LW00577	In classroom 220	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00578	In classroom 220	Classroom Combination Drinking Fountain	1.2	Pass	N/A	Testing complete
LW00579	In classroom 221	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00580	In classroom 221	Classroom Combination Drinking Fountain	1.2	Pass	N/A	Testing complete
LW00581	In classroom 101	Classroom Combination Sink	2.4	Pass	N/A	Testing complete
LW00583	In classroom 116	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00584	In classroom 117	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00587	In classroom 120	Classroom Combination Drinking Fountain	1.0	Pass	N/A	Testing complete
LW00588	In classroom 121	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00589	In classroom 311	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00591	In classroom 304	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00592	In classroom 312	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00594	In classroom 305	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW00595	In classroom 305	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW00596	In classroom 313	Classroom Sink	<1	Pass	N/A	Testing complete
LW00598	In classroom 306	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW02003	In classroom 306	Classroom Combination Drinking Fountain	1.0	Pass	N/A	Testing complete
LW02004	In classroom 314	Classroom Sink	2.6	Pass	N/A	Testing complete
LW02006	In classroom 307	Classroom Combination Sink	<1	Pass	N/A	Testing complete
LW02007	In classroom 307	Classroom Combination Drinking Fountain	1.7	Pass	N/A	Testing complete
LW02008	In classroom 315	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW02009	In classroom 308	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
LW02010	In classroom 316	Classroom Combination Drinking Fountain	1.2	Pass	N/A	Testing complete
LW02011	In classroom 309	Classroom Combination Drinking Fountain	16.3	Fail	NC	Remediation Action Plan
LW02013	In classroom 317	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
M00695	In break room	Teachers Lounge Sink	<1	Pass	N/A	Testing complete

M00697	In music 228 by music	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing complete
M00698	In classroom 230 left wall	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00710	In kitchen by kitchen	Kitchen Sink	1.2	Pass	N/A	Testing complete
M00711	In kitchen by kitchen	Kitchen Sink	<1	Pass	N/A	Testing complete
M00712	In kitchen by kitchen	Kitchen Sink	<1	Pass	N/A	Testing complete
M00728	In hallway hall left of CR 204	Drinking Fountain	<1	Pass	N/A	Testing complete
M00754	In hallway hall left of CR 116	Drinking Fountain	<1	Pass	N/A	Testing complete
M00755	In classroom 116	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00757	In classroom 117	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00759	In classroom 118	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00761	In classroom 120	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00763	In classroom 119	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00765	In classroom 121	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00774	In hallway hall left of CR 304	Drinking Fountain	<1	Pass	N/A	Testing complete
M00789	In classroom 315	Classroom Combination Sink	3.2	Pass	N/A	Testing complete
M00793	In classroom 316	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00795	In classroom 308	Classroom Combination Sink	<1	Pass	N/A	Testing complete
M00796	In classroom 309	Classroom Combination Sink	1.1	Pass	N/A	Testing complete
M00800	In classroom 311	Classroom Combination Sink	<1	Pass	N/A	Testing complete

NC - Not Collected (No follow-up sample collected due to COVID-19 (Coronavirus) Stay-at-Home Order.)



Montgomery County Public Schools Lead in Drinking Water Post-Remediation Follow-Up Testing 2019

August 30, 2019

Executive Summary:

New Hampshire Estates Elementary School

8720 Carroll Avenue

Silver Spring, Maryland 20903

Round of Testing:	Post-Remediation Follow-up
Sample Date	2/1/19
# of Outlets Tested:	1
# of Outlets ≥ 5 ppb:	0
Low Value (ppb):	1.4
High Value (ppb):	1.4

Project Status

Testing Complete: Post-remediation follow-up testing completed for following rooms:

Classroom 309 - Outlet (LW02011) will be placed back into service



August 30, 2019

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
8301 Turkey Thicket Dr., Bldg A, 1st Floor
Gaithersburg, Maryland 20879

Re: Lead in Water Post-Remediation Follow-up Testing Service

Location: New Hampshire Estates Elementary School

8720 Carroll Avenue
Silver Spring, Maryland 20903

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of the post-remediation follow-up lead in water testing at New Hampshire Estates Elementary School, located at 8720 Carroll Avenue in Silver Spring, Maryland 20903.

SCOPE OF SERVICES

One drinking water outlet was remediated at New Hampshire Estates Elementary School due to initial lead levels that exceeded the lead action level of 5 parts per billion (ppb). KCI Technologies, Inc. conducted lead in water post-remediation follow-up testing in accordance with the Maryland Code of Regulations (COMAR) 26.16.07 - Lead in Drinking Water - Public and Nonpublic Schools.

KCI Technologies, Inc. visited the site on 2/1/19 to collect a post-remediation follow-up sample from 1 drinking water outlet that had been replaced. The sample was submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

The initial, flush, and post-remediation follow-up results are highlighted in the summary table below:

Barcode ID	Room Number	Location	Notes	Equipment Type	Initial (ppb)	Flush (ppb)	Post-Remediation Follow-up (ppb)	Post-Remediation Follow-up Pass/Fail	Status
LW02011	309	Classroom		Bubbler - Indoor	42.5	N/A*	1.4	Pass	Post-remediation follow-up testing complete. Outlet will be placed back into service
*Fixture broken, could not be sampled and subsequently replaced									

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools. The Environmental Protection Agency (EPA) developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM
KCI Job #1214634186



MONTGOMERY COUNTY PUBLIC SCHOOLS LEAD IN DRINKING WATER TESTING 2018

Executive Summary:
New Hampshire Estates
Elementary School
8720 Carroll Avenue
Silver Spring, MD 20903

Date of Test Report:	03/12/2018
Round of Testing:	Initial
# of Outlets Tested:	84
# of Outlets \geq 20 ppb:	1
Low Value (ppb):	< 1.0
High Value (ppb):	42.5

Project Status

Initial testing complete: Follow up testing required for 1 samples \geq 20 ppb.

Drinking Outlets results > 20 ppb

Room 309 (42.5 ppb)



March 12, 2018

Mr. Brian Mullikin
Environmental Team Leader
Montgomery County Public Schools
8301 Turkey Thicket Drive
Building A, First Floor
Gaithersburg, Maryland 20879

Re: Lead in Water Testing Service

Location: New Hampshire Elementary School
8720 Carroll Avenue
Silver Spring, MD 20903

Dear Mr. Mullikin:

Professional Services Industries (PSI), Inc. is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of initial lead in water testing at New Hampshire Estates Elementary School, located at 8720 Carroll Avenue in Silver Spring, MD 20903.

Scope of Services:

PSI conducted lead in water testing at New Hampshire Estates Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

PSI visited the site on 02/08/18 and 02/09/18 to collect samples from 86 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water—Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

Results:

There was one result of the lead in water analysis at or above 20 parts per billion (ppb) and is highlighted in the summary table below:



Barcode ID	Date Collected	Sample Location	Sample Result (ppb)
LW02011	02/09/18	Bubbler– Classroom 309	42.5

The lead in water sample results for sample collection date 02/09/18 are shown in Attachment A.

Discussion:

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children’s brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990’s could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,

PROFESSIONAL SERVICE INDUSTRIES, INC.

Nand Kaushik, P.E.
Department Manager, Environmental Services
Nand.Kaushik@psiusa.com

Attachments: A – Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: Professional Services Industries, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Sample Results for New Hampshire Estates Elementary School

Barcode ID	Room Number	Location	Location Notes	Equipment Type	Result (PPB)*	Pass/Fail	Status
LW00543		Hallway	Next To Gym	Cooler	<1.0	Pass	Testing Complete
LW00544		Cafeteria	Right Of Kitchen	Cooler	<1.0	Pass	Testing Complete
LW00545	228	Music		Faucet	1.3	Pass	Testing Complete
LW00546		Work Room Media Center		Faucet	1.8	Pass	Testing Complete
LW00547	230	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00549	231	Art		Faucet	<1.0	Pass	Testing Complete
LW00550	231	Art		Faucet	6.9	Pass	Testing Complete
LW00551	231	Art		Faucet	3.5	Pass	Testing Complete
LW00552	231	Art		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00553	231	Art		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00555		Work Room Administration		Faucet	<1.0	Pass	Testing Complete
LW00556		Health Room		Faucet	<1.0	Pass	Testing Complete
LW00557	H-8	Health Room		Faucet	1.3	Pass	Testing Complete
LW00558	H-11	Health Room		Faucet	1	Pass	Testing Complete
LW00559	H-9	Health Room		Faucet	1.7	Pass	Testing Complete
LW00560	215	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00561	251	Classroom		Bubbler - Indoor	2.5	Pass	Testing Complete
LW00562	204	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00563	204	Classroom		Bubbler - Indoor	1.9	Pass	Testing Complete
LW00564	216	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00565	216	Classroom		Bubbler - Indoor	1.1	Pass	Testing Complete
LW00566	205	Classroom		Faucet	1.7	Pass	Testing Complete

Barcode ID	Room Number	Location	Location Notes	Equipment Type	Result (PPB)*	Pass/Fail	Status
LW00567	205	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00568	217	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00569	217	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00570	206	Classroom		Faucet	1	Pass	Testing Complete
LW00571	206	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00572	218	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00573	218	Classroom		Bubbler - Indoor	2	Pass	Testing Complete
LW00574	219	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00575	219	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00576	209	Office		Faucet	3.2	Pass	Testing Complete
LW00577	220	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00578	220	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00579	221	Classroom		Faucet	<1.0	Pass	Testing Complete
LW00580	221	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00581	101	Classroom		Faucet	4.2	Pass	Testing Complete
LW00583	116	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00584	117	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00585	118	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00586	119	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00587	120	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00588	121	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00589	311	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00590	304	Classroom		Faucet	1.2	Pass	Testing Complete
LW00591	304	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW00592	312	Classroom		Faucet	2.9	Pass	Testing Complete
LW00593	312	Classroom		Bubbler - Indoor	9.9	Pass	Testing Complete
LW00594	305	Classroom		Faucet	1	Pass	Testing Complete
LW00595	305	Classroom		Bubbler - Indoor	1.6	Pass	Testing Complete

Barcode ID	Room Number	Location	Location Notes	Equipment Type	Result (PPB)*	Pass/Fail	Status
LW00596	313	Classroom		Faucet	4.4	Pass	Testing Complete
LW00597	313	Classroom		Bubbler - Indoor	7.1	Pass	Testing Complete
LW00598	306	Classroom		Faucet	1.2	Pass	Testing Complete
LW02003	306	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW02004	314	Classroom		Faucet	3.2	Pass	Testing Complete
LW02005	314	Classroom		Bubbler - Indoor	11	Pass	Testing Complete
LW02006	307	Classroom		Faucet	<1.0	Pass	Testing Complete
LW02007	307	Classroom		Bubbler - Indoor	3.3	Pass	Testing Complete
LW02008	315	Classroom		Bubbler - Indoor	1	Pass	Testing Complete
LW02009	308	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW02010	316	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW02011	309	Classroom		Bubbler - Indoor	42.5	Fail	Follow-Up Testing Needed
LW02012	317	Classroom		Faucet	1.9	Pass	Testing Complete
LW02013	317	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M00695		Break Room		Faucet	<1.0	Pass	Testing Complete
M00697	228	Music		Bubbler - Indoor	<1.0	Pass	Testing Complete
M00698	230	Classroom		Faucet	<1.0	Pass	Testing Complete
M00710		Kitchen		Faucet	1.9	Pass	Testing Complete
M00711		Kitchen		Faucet	<1.0	Pass	Testing Complete
M00712		Kitchen		Faucet	3.4	Pass	Testing Complete
M00728		Hallway	Hall Left of CR 204	Cooler	<1.0	Pass	Testing Complete
M00754		Hallway	Hall Left of CR 116	Cooler	<1.0	Pass	Testing Complete
M00755	116	Classroom		Faucet	1.3	Pass	Testing Complete
M00757	117	Classroom		Faucet	1.3	Pass	Testing Complete
M00759	118	Classroom		Faucet	<1.0	Pass	Testing Complete
M00761	120	Classroom		Faucet	<1.0	Pass	Testing Complete
M00763	119	Classroom		Faucet	4.2	Pass	Testing Complete
M00765	121	Classroom		Faucet	<1.0	Pass	Testing Complete

Barcode ID	Room Number	Location	Location Notes	Equipment Type	Result (PPB)*	Pass/Fail	Status
M00774		Hallway	Hall Left of CR 304	Cooler	<1.0	Pass	Testing Complete
M00789	315	Classroom		Faucet	<1.0	Pass	Testing Complete
M00793	316	Classroom		Faucet	<1.0	Pass	Testing Complete
M00795	308	Classroom		Faucet	<1.0	Pass	Testing Complete
M00796	309	Classroom		Faucet	<1.0	Pass	Testing Complete
M00800	311	Classroom		Faucet	1.7	Pass	Testing Complete

*ppb = parts per billion