



Montgomery County Public Schools Lead in Drinking Water Testing 2018

May 24, 2018

Executive Summary:

Roscoe R. Nix Elementary School

1100 Corliss Street

Silver Spring, Maryland 20903

Round of Testing:	Initial
# of Outlets Tested:	56
# of Outlets ≥ 20 ppb:	0
Low Value (ppb):	<1.0
High Value (ppb):	14.2

Project Status:

Testing Complete: All results less than 20 ppb.



May 24, 2018

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Drinking Water Testing

KCI Job #1214634193

Location: Roscoe R. Nix Elementary School

1100 Corliss Street
Silver Spring, Maryland 20903

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of Initial lead in water testing at Roscoe R. Nix Elementary School, located at 1100 Corliss Street in Silver Spring, Maryland 20903.

SCOPE OF SERVICES

KCI conducted lead in water testing at Roscoe R. Nix Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

KCI visited the site on 4/19/2018 and 4/20/2018 to collect samples from 56 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water - Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

There are no results of the lead in water analysis at or above 20 parts per billion (ppb). The lead in water sample results for sample collection date 4/20/2018 are shown in Attachment A.

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM

Attachment:

A- Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: KCI Technologies, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Sample Results for Roscoe R. Nix Elementary School

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
LW05779	237D	Resource Center		Faucet	<1.0	Pass	Testing Complete
LW05780	159	Classroom		Faucet	<1.0	Pass	Testing Complete
LW05781	159	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW05782	156	Classroom		Faucet	<1.0	Pass	Testing Complete
LW05783	156	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW05784	151	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW05785	148	Classroom		Faucet	<1.0	Pass	Testing Complete
LW05786	148	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW05789	100G	Break Room		Faucet	<1.0	Pass	Testing Complete
LW11414	100G	Break Room		Instant Hot Water	<1.0	Pass	Testing Complete
LW11415	102D	Health Room		Faucet	<1.0	Pass	Testing Complete
LW11416	102G	Health Room		Faucet	14.2	Pass	Testing Complete
M28683		Hallway	Next To 172	Cooler	<1.0	Pass	Testing Complete
M28684		Hallway	Next To 172	Cooler	<1.0	Pass	Testing Complete
M28690	162	Classroom		Faucet	<1.0	Pass	Testing Complete
M28693	166	Classroom		Faucet	<1.0	Pass	Testing Complete
M28695	170	Classroom		Faucet	<1.0	Pass	Testing Complete
M28697	165	Special Ed		Faucet	<1.0	Pass	Testing Complete
M28703	160	Classroom		Faucet	<1.0	Pass	Testing Complete
M28704	160	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M28709	155	Classroom		Faucet	<1.0	Pass	Testing Complete

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
M28710	155	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M28712	152	Classroom		Faucet	<1.0	Pass	Testing Complete
M28713	152	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M28715	151	Classroom		Faucet	<1.0	Pass	Testing Complete
M28718	147	Classroom		Faucet	<1.0	Pass	Testing Complete
M28719	147	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M28725	146	Classroom		Faucet	<1.0	Pass	Testing Complete
M28727	142	Classroom		Faucet	<1.0	Pass	Testing Complete
M28728		Hallway	Next To 136	Cooler	<1.0	Pass	Testing Complete
M28729		Hallway	Next To 136	Cooler	<1.0	Pass	Testing Complete
M28738		Hallway	Next To 120	Cooler	<1.0	Pass	Testing Complete
M28739		Hallway	Next To 120	Cooler	<1.0	Pass	Testing Complete
M28751		Kitchen		Faucet	3.9	Pass	Testing Complete
M28752		Kitchen		Faucet	2.7	Pass	Testing Complete
M28753		Kitchen		Faucet	1.4	Pass	Testing Complete
M28754		Kitchen		Faucet	<1.0	Pass	Testing Complete
M28757	104	Work Room		Faucet	1.3	Pass	Testing Complete
M28761	244	Classroom		Faucet	<1.0	Pass	Testing Complete
M28763	240	Classroom		Faucet	<1.0	Pass	Testing Complete
M28764	236	Classroom		Faucet	1.0	Pass	Testing Complete
M28765	235	Classroom		Faucet	<1.0	Pass	Testing Complete
M28766	234	Classroom		Faucet	<1.0	Pass	Testing Complete
M28767	231	Classroom		Faucet	<1.0	Pass	Testing Complete
M28769	230	Classroom		Faucet	<1.0	Pass	Testing Complete
M28770	229	Classroom		Faucet	<1.0	Pass	Testing Complete

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
M28771	213	Classroom		Faucet	<1.0	Pass	Testing Complete
M28785		Hallway	Next To 224	Cooler	<1.0	Pass	Testing Complete
M28786		Hallway	Next To 224	Cooler	<1.0	Pass	Testing Complete
M28787	211	Classroom		Faucet	<1.0	Pass	Testing Complete
M28788	212	Classroom		Faucet	<1.0	Pass	Testing Complete
M28789	207	Classroom		Faucet	<1.0	Pass	Testing Complete
M28790	208	Classroom		Faucet	<1.0	Pass	Testing Complete
M28791	204	Classroom		Faucet	<1.0	Pass	Testing Complete
M28792	200	Classroom		Faucet	<1.0	Pass	Testing Complete
M28793	203D	Staff Development		Faucet	<1.0	Pass	Testing Complete

*PPB = parts per billion