

Montgomery County Public Schools Lead in Drinking Water Testing Report

Takoma Park Elementary School
7511 Holly Ave.
Takoma Park, MD 20912

Report Date: April 14th, 2020

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

| | |
|---------------------------|-----------|
| Sampling Date | 2/20/2020 |
| # of Outlets Tested | 84 |
| # of Outlets \geq 5 ppb | 2 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Takoma Park ES

| Fixture Barcode | Fixture Location | Fixture Type | Initial Results (ppb) | Pass/Fail | Follow up Results (ppb) | Status |
|-----------------|---|---|-----------------------|-----------|-------------------------|-------------------------|
| LW02094 | In classroom 322 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02096 | In classroom 314 | Classroom Combination Sink | 1.5 | Pass | N/A | Testing Complete |
| LW02097 | In classroom 314 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02100 | In classroom 315 | Classroom Combination Sink | 1.1 | Pass | N/A | Testing Complete |
| LW02101 | In hallway next to music room 313 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02102 | In music 309 | Classroom Sink | 2.2 | Pass | N/A | Testing Complete |
| LW02104 | In all purpose room inside of Multipurpose room | Classroom Sink | 1.0 | Pass | N/A | Testing Complete |
| LW02105 | In cafeteria | Kitchen Sink | 2.8 | Pass | N/A | Testing Complete |
| LW02106 | In cafeteria | Kitchen Sink | 3.3 | Pass | N/A | Testing Complete |
| LW02107 | In cafeteria | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| LW02108 | In cafeteria | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| LW02110 | In cafeteria | Ice Machine | <1 | Pass | N/A | Testing Complete |
| LW02111 | In work room 300D | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW02112 | In health room 301 | Nurses Office Sink | <1 | Pass | N/A | Testing Complete |
| LW02113 | In classroom 401 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW02114 | In classroom 401 | Classroom Combination Drinking Fountain | 1.2 | Pass | N/A | Testing Complete |
| LW02116 | In classroom 404 | Classroom Combination Drinking Fountain | 4.7 | Pass | N/A | Testing Complete |
| LW02120 | In hallway across from media center | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02123 | In classroom 509 | Classroom Combination Drinking Fountain | 6.0 | Fail | <1 | Remediation Action Plan |
| LW02124 | In classroom 507 | Classroom Combination Sink | 1.0 | Pass | N/A | Testing Complete |
| LW02126 | In classroom 510 | Classroom Sink | 3.0 | Pass | N/A | Testing Complete |
| LW02127 | In classroom 500 | Classroom Combination Sink | 2.0 | Pass | N/A | Testing Complete |
| LW02128 | In classroom 500 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02130 | In classroom 204 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02131 | In classroom 202 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW02132 | In classroom 202 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02133 | In classroom 202 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02134 | In classroom 205 | Classroom Sink | 1.9 | Pass | N/A | Testing Complete |
| LW02135 | In hallway next to gymnasium | Drinking Fountain | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|---------|---|---|----|------|-----|------------------|
| LW02136 | In hallway next to gym | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02137 | In hallway across from 128 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08902 | In classroom 318 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08903 | In classroom 318 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08904 | In classroom 319 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08905 | In classroom 319 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08906 | In classroom 321 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08907 | In classroom 321 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08908 | In classroom 322 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08910 | In classroom 326 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08911 | In classroom 326 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08912 | In classroom 328 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08914 | In classroom 328 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08915 | In classroom 330 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08916 | In classroom 330 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08917 | In classroom 332 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08918 | In classroom 332 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08919 | In classroom 336 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08920 | In classroom 336 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08924 | In hallway across from CR 340 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08925 | In hallway across from CR 340 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08930 | In classroom 340 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08931 | In classroom 340 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08934 | In break room 348 | Teachers Lounge Sink | <1 | Pass | N/A | Testing Complete |
| M08936 | In media center 400D by media center ie. inside IMC | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| M08937 | In classroom 107 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08938 | In classroom 107 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08940 | In classroom 106 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08941 | In classroom 106 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08943 | In classroom 109 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08944 | In classroom 109 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08946 | In classroom 111 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|---------|--------------------------------------|---|-----|------|-----|-------------------------|
| M08947 | In classroom 111 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08949 | In classroom 113 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08950 | In classroom 113 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08953 | In classroom 120 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08954 | In classroom 120 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08956 | In classroom 124 | Classroom Combination Sink | 4.2 | Pass | N/A | Testing Complete |
| M08957 | In classroom 124 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08959 | In classroom 126 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08960 | In classroom 126 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08962 | In classroom 128 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08963 | In classroom 128 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08965 | In hallway across from CR 128 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08967 | In classroom 200 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M08968 | In classroom 200 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M08971 | In classroom 200A inside CR 200 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| M22734 | In hallway next to boys | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M22782 | In classroom 205 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02109 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M08935 | In media center 400 | Classroom Sink | 1.5 | Pass | N/A | Testing Complete |
| LW08349 | In hallway adjacent to Classroom 407 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW02115 | In Classroom 404 | Classroom Combination Sink | 5.4 | Fail | <1 | Remediation Action Plan |
| LW02122 | In Classroom room 509 | Classroom Combination Sink | 1.4 | Pass | N/A | Testing Complete |
| LW02129 | In Classroom 204 | Classroom Sink | 3.2 | Pass | N/A | Testing Complete |



**MONTGOMERY COUNTY PUBLIC SCHOOLS LEAD IN DRINKING WATER
POST-REMEDATION FOLLOW-UP TESTING 2019**

August 29, 2019

Executive Summary:

Takoma Park Elementary School

7511 Holly Avenue, Takoma Park, MD 20912

| Round of Testing: | Post-Remediation Follow-Up |
|----------------------------|-----------------------------------|
| Sample Date | 02/06/2019 |
| # of Outlets Tested: | 1 |
| # of Outlets \geq 5 ppb: | 0 |
| Low Value (ppb): | 3.4 |
| High Value (ppb): | 3.4 |

Project Status

Testing Complete: Post-remediation follow-up testing completed for following rooms:

Classroom 500: Outlet (LW02127) will be placed back into service



August 29, 2019

Mr. Brian Mullikin
Environmental Team Leader
Montgomery County Public Schools
8301 Turkey Thicket Drive
Building A, First Floor
Gaithersburg, Maryland 20879

Re: Lead in Water Post-remediation follow-up Testing Service

Location: Takoma Park Elementary School,
7511 Holly Avenue,
Takoma Park, MD 20912

Dear Mr. Mullikin:

Intertek-PSI Inc. is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of the post-remediation lead in water testing at Takoma Park Elementary School, located at 7511 Holly Avenue, Takoma Park, MD 20912.

Scope of Services:

One (1) drinking water outlet was remediated at Takoma Park Elementary School due to initial lead levels that exceeded the lead action level of 5 parts per billion (ppb). Intertek-PSI conducted lead in water post-remediation follow-up testing in accordance with the Maryland Code of Regulations (COMAR) 26.16.07 - Lead in Drinking Water—Public and Nonpublic Schools.

Intertek-PSI visited the site on 02/05/2019 and 02/06/2019 to collect post-remediation follow-up sample from 1 drinking water outlet that had been replaced. Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

Results:

The initial, flush, and post-remediation results are highlighted in the summary table below:



| Barcode ID | Room Number | Location | Notes | Equipment Type | Initial (ppb) | Flush (ppb) | Post-remediation follow-up (ppb) | Post-remediation follow-up Pass/Fail | Status |
|------------|-------------|-----------|-------|----------------|---------------|-------------|----------------------------------|--------------------------------------|--|
| LW02127 | 500 | Classroom | | Faucet | 39.2 | 13.3 | 3.4 | Pass | Post-remediation follow-up testing complete. Outlet will be placed back into service |

Discussion:

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children’s brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990’s could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools. The Environmental Protection Agency (EPA) developed the 3T’s (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T’s can be found on the EPA website.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children’s hands, bottles, pacifiers and toys often.

Respectfully Submitted,

INTERTEK-PSI

Nan Lin
Department Manager, Environmental Services
nan.lin@intertek.com



MONTGOMERY COUNTY PUBLIC SCHOOLS DRINKING WATER TESTING 2018

April 24, 2018

Executive Summary:
Takoma Park Elementary School
7511 Holly Avenue
Takoma Park, MD 20912

| | |
|--|--------------------------|
| Round of Testing: | Initial |
| # of Outlets Tested: | 84 |
| # of Outlets \geq 20 ppb: | 1 |
| Low Value (ppb): | < 1.0 |
| High Value (ppb): | 39.2 |
| Follow-Up Testing Required (Samples \geq 20 ppb): | Classroom 500 (39.2 ppb) |

| | |
|----------------------|-------------------------|
| Round of Testing: | Follow-Up – 30 sec draw |
| # of Outlets Tested: | 1 |

Project Status
Testing Complete: Remediation Plan

Classroom 500 – Replace fixture (LW02127), in addition to supply line and valve located under sink



April 24, 2018

Mr. Brian Mullikin
Environmental Team Leader
Montgomery County Public Schools
8301 Turkey Thicket Drive
Building A, First Floor
Gaithersburg, Maryland 20879

Re: Lead in Water Testing Service

Location: Takoma Park Elementary School
7511 Holly Avenue
Takoma Park, MD 20912

Dear Mr. Mullikin:

Professional Services Industries (PSI), Inc. is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of initial lead in water testing at Takoma Park Elementary School, located at 7511 Holly Avenue in Takoma Park, MD 20912.

Scope of Services:

PSI conducted lead in water testing at Takoma Park Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

PSI visited the site on 02/13/18 and 02/14/18 to collect samples from 84 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water—Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07. One 30 second follow-up sample was collected on 4/11/18.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

Results:

There was one result of the initial lead in water analysis at or above 20 parts per billion (ppb) and subsequent follow up 30 second results are highlighted in the summary table below:



| Barcode ID | Sample Location | Date Collected | Initial Sample Result (ppb) | Date Collected | 30 Second Follow Up Sample Result (ppb) |
|------------|-----------------|----------------|-----------------------------|----------------|---|
| LW02127 | Classroom 500 | 2/14/2018 | 39.2 | 4/11/18 | 23.1 |

The initial lead in water sample results (02/14/18) and 30 second follow up results (4/11/18) are shown in Attachment A.

Discussion:

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children’s brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990’s could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,

PROFESSIONAL SERVICE INDUSTRIES, INC.

Nand Kaushik, P.E.
Department Manager, Environmental Services
Nand.Kaushik@psiusa.com

Attachments: A – Lead in Water Test Summary Table

ATTACHMENT A

Takoma Park ES Water Test Summary Table

Contractor: Professional Services Industries, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Initial Sample Results for Takoma Park Elementary School (2/14/18)

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results | Pass/Fail | Status |
|------------|--------|------------------|-----------------------------|------------------|---------|-----------|------------------|
| LW02094 | 322 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW02095 | 317 | Classroom | | Faucet | 5.1 | Pass | Testing Complete |
| LW02096 | 314 | Classroom | | Faucet | 2.9 | Pass | Testing Complete |
| LW02097 | 314 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW02098 | 316 | Classroom | | Faucet | 11.4 | Pass | Testing Complete |
| LW02099 | 316 | Classroom | | Bubbler - Indoor | 5.7 | Pass | Testing Complete |
| LW02100 | 315 | Classroom | | Faucet | 4.5 | Pass | Testing Complete |
| LW02101 | | Hallway | Next To Music Room 313 | Cooler | <1.0 | Pass | Testing Complete |
| LW02102 | 309 | Music | | Faucet | 3.8 | Pass | Testing Complete |
| LW02104 | | All Purpose Room | Inside Of Multipurpose Room | Faucet | 2.1 | Pass | Testing Complete |
| LW02105 | | Cafeteria | | Faucet | 3.4 | Pass | Testing Complete |
| LW02106 | | Cafeteria | | Faucet | 4.0 | Pass | Testing Complete |
| LW02107 | | Cafeteria | | Faucet | 1.8 | Pass | Testing Complete |
| LW02108 | | Cafeteria | | Faucet | 2.3 | Pass | Testing Complete |
| LW02109 | | Cafeteria | | Faucet | 7.6 | Pass | Testing Complete |
| LW02110 | | Cafeteria | | Icemaker | <1.0 | Pass | Testing Complete |
| LW02111 | 300D | Work Room | | Faucet | 2.7 | Pass | Testing Complete |
| LW02112 | 301 | Health Room | | Faucet | <1.0 | Pass | Testing Complete |
| LW02113 | 401 | Classroom | | Faucet | 2.9 | Pass | Testing Complete |
| LW02115 | 404 | Classroom | | Faucet | 8.6 | Pass | Testing Complete |
| LW02120 | | Hallway | Across From Media Center | Cooler | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results | Pass/Fail | Status |
|------------|--------|-----------|-----------------|------------------|---------|-----------|--------------------------|
| LW02121 | 508 | Classroom | | Faucet | 6.6 | Pass | Testing Complete |
| LW02122 | 509 | Classroom | | Faucet | 7.4 | Pass | Testing Complete |
| LW02123 | 509 | Classroom | | Bubbler - Indoor | 1.8 | Pass | Testing Complete |
| LW02124 | 507 | Classroom | | Faucet | 3.6 | Pass | Testing Complete |
| LW02125 | 507 | Classroom | | Bubbler - Indoor | 3.8 | Pass | Testing Complete |
| LW02126 | 510 | Classroom | | Faucet | 3.5 | Pass | Testing Complete |
| LW02127 | 500 | Classroom | | Faucet | 39.2 | Fail | Follow-Up Testing Needed |
| LW02128 | 500 | Classroom | | Faucet | 2.7 | Pass | Testing Complete |
| LW02129 | 204 | Classroom | | Faucet | 6.6 | Pass | Testing Complete |
| LW02130 | 204 | Classroom | | Cooler | 1.5 | Pass | Testing Complete |
| LW02131 | 202 | Classroom | | Faucet | 2.1 | Pass | Testing Complete |
| LW02132 | 202 | Classroom | | Bubbler - Indoor | 1.3 | Pass | Testing Complete |
| LW02133 | 202 | Classroom | | Cooler | 1.2 | Pass | Testing Complete |
| LW02134 | 205 | Classroom | | Faucet | 4.5 | Pass | Testing Complete |
| LW02136 | | Hallway | Next To Gym | Cooler | <1.0 | Pass | Testing Complete |
| LW02137 | | Hallway | Across From 128 | Cooler | <1.0 | Pass | Testing Complete |
| M08902 | 318 | Classroom | | Faucet | 1.8 | Pass | Testing Complete |
| M08903 | 318 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08904 | 319 | Classroom | | Faucet | 1.0 | Pass | Testing Complete |
| M08905 | 319 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08906 | 321 | Classroom | | Faucet | 1.1 | Pass | Testing Complete |
| M08907 | 321 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08908 | 322 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08910 | 326 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08911 | 326 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08912 | 328 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08914 | 328 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results | Pass/Fail | Status |
|------------|--------|--------------|--------------------|------------------|---------|-----------|------------------|
| M08915 | 330 | Classroom | | Faucet | 1.0 | Pass | Testing Complete |
| M08916 | 330 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08917 | 332 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08918 | 332 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08919 | 336 | Classroom | | Faucet | 3.2 | Pass | Testing Complete |
| M08920 | 336 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08924 | | Hallway | Across from CR 340 | Cooler | <1.0 | Pass | Testing Complete |
| M08925 | | Hallway | Across from CR 340 | Cooler | <1.0 | Pass | Testing Complete |
| M08930 | 340 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08931 | 340 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08934 | 348 | Break Room | | Faucet | <1.0 | Pass | Testing Complete |
| M08935 | 400 | Media Center | | Faucet | 12.3 | Pass | Testing Complete |
| M08936 | 400D | Media Center | Inside IMC | Faucet | 1.8 | Pass | Testing Complete |
| M08937 | 107 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08938 | 107 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08940 | 106 | Classroom | | Faucet | 1.1 | Pass | Testing Complete |
| M08941 | 106 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08943 | 109 | Classroom | | Faucet | 1.1 | Pass | Testing Complete |
| M08944 | 109 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08946 | 111 | Classroom | | Faucet | 1.1 | Pass | Testing Complete |
| M08947 | 111 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08949 | 113 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08950 | 113 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08953 | 120 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08954 | 120 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08956 | 124 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08957 | 124 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results | Pass/Fail | Status |
|------------|--------|-----------|--------------------|------------------|---------|-----------|------------------|
| M08959 | 126 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08960 | 126 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08962 | 128 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08963 | 128 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08965 | | Hallway | Across from CR 128 | Cooler | <1.0 | Pass | Testing Complete |
| M08967 | 200 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M08968 | 200 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M08971 | 200A | Classroom | Inside CR 200 | Faucet | <1.0 | Pass | Testing Complete |
| M22782 | 205 | Classroom | | Cooler | <1.0 | Pass | Testing Complete |

*ppb = parts per billion

Contractor: Professional Services Industries, Inc.
Certified Laboratory: Microbac Laboratories, Inc.

Follow Up Sample Results for Takoma Park Elementary School (4/11/18)

| Barcode ID | Room Number | Location | Equipment Type | Initial draw (2 nd) (PPB) | Initial draw (3 rd) (PPB) | 30 Second Draw (PPB) | Status |
|------------|-------------|-----------|----------------|---------------------------------------|---------------------------------------|----------------------|---|
| LW02127 | 500 | Classroom | Faucet | 13.3 | 1400 | 23.1 | Remediation required – replace fixture, in addition to supply line and valve located under sink |

*ppb = parts per billion

Note: Fixture(s) with elevated test results were immediately removed from service. Subsequent 2nd and 3rd round testing was performed on these fixture(s) for further diagnostics for remediation. Because the fixture was shut off after the first test, the subsequent test results may not be representative of an in-use fixture because of stagnant water in the supply line and the operation of shut off valves prior to the tests. All fixtures with elevated test results are to be remediated. After remediation, post remediation testing will be conducted before the fixture is returned to service.