

Montgomery County Public Schools Lead in Drinking Water Testing Report

Walter Johnson High School
6400 Rock Spring Drive
Bethesda, MD 20814

Report Date: July 25th, 2023

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by Inspection Experts Inc. is presented in the table below.

| | |
|---------------------------|---------|
| Sampling Date | 4/18/23 |
| # of Outlets Tested | 52 |
| # of Outlets \geq 5 ppb | 5 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the workplace and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s):

A - Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Walter Johnson HS

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|----------------|---|--------------------------|------------------------|-----------|-------------------------|
| LW05322 | In hallway Close to 129 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW05323 | In hallway Close to 129 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW05325 | In work room 104 | Teachers Lounge Sink | <1.0 | Pass | Testing Complete |
| LW05327 | In concession 197C | Ice Machine | <1.0 | Pass | Testing Complete |
| LW05369 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| LW05370 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| LW05371 | In kitchen | Kitchen Sink | 1.1 | Pass | Testing Complete |
| LW05372 | In kitchen | Kitchen Sink | 1.5 | Pass | Testing Complete |
| LW05373 | In kitchen | Kitchen Sink | 3.8 | Pass | Testing Complete |
| LW05374 | In kitchen | Kitchen Sink | 1.4 | Pass | Testing Complete |
| LW05375 | In break room 170C by cafeteria | Teachers Lounge Sink | 2.3 | Pass | Testing Complete |
| LW05376 | In cafeteria next to 170c | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW05379 | In concession 190B across from auditorium | Ice Machine | <1.0 | Pass | Testing Complete |
| LW05381 | In health room 154 | Nurses Office Sink | <1.0 | Pass | Testing Complete |
| LW05382 | In work room 151 by office | Teachers Lounge Sink | <1.0 | Pass | Testing Complete |
| LW05385 | In hallway next to gym | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW06464 | In Weight room G65 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW06465 | In classroom G07 | Classroom Sink | <1.0 | Pass | Testing Complete |
| LW06472 | In classroom G07 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW06473 | In home economics G02 | Home Economics Room Sink | 5.2 | Fail | Remediation Action Plan |

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|-----------------------|--------------------------------------|--------------------------|-------------------------------|------------------|-------------------------|
| LW06474 | In home economics G02 | Home Economics Room Sink | 6.1 | Fail | Remediation Action Plan |
| LW06475 | In home economics G02 | Home Economics Room Sink | 14.5 | Fail | Remediation Action Plan |
| LW06476 | In home economics G02 | Home Economics Room Sink | 6.2 | Fail | Remediation Action Plan |
| LW06477 | In home economics G02 | Home Economics Room Sink | 2.9 | Pass | Testing Complete |
| LW06478 | In home economics G02 | Home Economics Room Sink | 3.0 | Pass | Testing Complete |
| LW06479 | In home economics G02 | Home Economics Room Sink | 7.3 | Fail | Remediation Action Plan |
| LW06480 | In hallway across from G15C | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW06481 | In hallway G15C | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW06484 | In work room 244 | Teachers Lounge Sink | 1.8 | Pass | Testing Complete |
| LW06485 | In hallway 212 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08359 | In hallway adjacent to gymnasium 199 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08360 | In cafeteria adjacent to 170C | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08361 | In hallway adjacent to room 119C | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08458 | In hallway adjacent to room G15C | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08459 | In hallway adjacent to room G55 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08460 | In Boys Locker room G57 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08461 | In Girl's locker room G62 | Drinking Fountain | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|-----------------------|---|--------------------|-------------------------------|------------------|------------------|
| LW08462 | In hallway adjacent to room G65 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07586 | In training room G59 | Ice Machine | <1.0 | Pass | Testing Complete |
| M07587 | In hallway G55 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07588 | In hallway G55 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07610 | In Weight room G65 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07619 | In concession 197C | Concession Sink | 2.8 | Pass | Testing Complete |
| M20409 | In kitchen | Ice Machine | <1.0 | Pass | Testing Complete |
| M20413 | In kitchen by back wall | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M20416 | In kitchen by outside wall | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M20417 | In kitchen by outside wall | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M20421 | In kitchen serving area | Kitchen Sink | 4.6 | Pass | Testing Complete |
| M26345 | In hallway next to elevator and 261 storage | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M26350 | In hallway 261 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW05582 | In hallway right of 212 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW05583 | In hallway 261 | Drinking Fountain | <1.0 | Pass | Testing Complete |

Montgomery County Public Schools Lead in Drinking Water Testing Report

Walter Johnson High School
6400 Rock Spring Drive
Bethesda, MD 20814

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

| | |
|---------------------------|-----------|
| Sampling Date | 2/27/2020 |
| # of Outlets Tested | 65 |
| # of Outlets \geq 5 ppb | 0 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Walter Johnson HS

| Fixture Barcode | Fixture Location | Fixture Type | Initial Results (ppb) | Pass/Fail | Follow up Results (ppb) | Status |
|-----------------|---|----------------------|-----------------------|-----------|-------------------------|------------------|
| LW05322 | In hallway Close to 129 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05323 | In hallway Close to 129 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05324 | In work room 128 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW05325 | In work room 104 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW05326 | In classroom 158 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW05327 | In concession 197C | Ice Machine | <1 | Pass | N/A | Testing Complete |
| LW05369 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| LW05370 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| LW05371 | In kitchen | Kitchen Sink | 1.5 | Pass | N/A | Testing Complete |
| LW05372 | In kitchen | Kitchen Sink | 1.5 | Pass | N/A | Testing Complete |
| LW05373 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| LW05374 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| LW05375 | In break room 170C by cafeteria | Teachers Lounge Sink | 1.1 | Pass | N/A | Testing Complete |
| LW05376 | In cafeteria next to 170c | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05377 | In office 173 by Band | Classroom Sink | 2.5 | Pass | N/A | Testing Complete |
| LW05379 | In concession 190B across from auditorium | Ice Machine | <1 | Pass | N/A | Testing Complete |
| LW05380 | In classroom 166 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW05381 | In health room 154 | Nurses Office Sink | <1 | Pass | N/A | Testing Complete |
| LW05382 | In work room 151 by office | Teachers Lounge Sink | <1 | Pass | N/A | Testing Complete |
| LW05383 | In office 100 by office | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW05384 | In work room 155C by counselor | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW05385 | In hallway next to gym | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05386 | In english office 142 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW06462 | In hallway G85 across from | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW06463 | In hallway G85 across from | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW06464 | In Weight room G65 next to | Drinking Fountain | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|---------|--|--------------------------|-----|------|-----|------------------|
| LW06465 | In classroom G07 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW06472 | In classroom G07 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW06473 | In home economics G02 | Home Economics Room Sink | <1 | Pass | N/A | Testing Complete |
| LW06474 | In home economics G02 | Home Economics Room Sink | <1 | Pass | N/A | Testing Complete |
| LW06475 | In home economics G02 | Home Economics Room Sink | <1 | Pass | N/A | Testing Complete |
| LW06476 | In home economics G02 | Home Economics Room Sink | <1 | Pass | N/A | Testing Complete |
| LW06477 | In home economics G02 | Home Economics Room Sink | <1 | Pass | N/A | Testing Complete |
| LW06478 | In home economics G02 | Home Economics Room Sink | <1 | Pass | N/A | Testing Complete |
| LW06479 | In home economics G02 | Home Economics Room Sink | <1 | Pass | N/A | Testing Complete |
| LW06480 | In hallway across from G15C | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW06481 | In hallway G15C across from | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW06482 | In work room G44 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW06483 | In training room G59 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| LW06484 | In work room 244 | Teachers Lounge Sink | 2.4 | Pass | N/A | Testing Complete |
| LW06485 | In hallway 212 right of | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M07583 | In work room G27 | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| M07586 | In training room G59 | Ice Machine | <1 | Pass | N/A | Testing Complete |
| M07587 | In hallway G55 next to G55 Football office | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M07588 | In hallway G55 next to G55 Football office | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M07610 | In Weight room G65 next to G65 Weight | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M07619 | In concession 197C | Classroom Sink | <1 | Pass | N/A | Testing Complete |
| M20409 | In kitchen by kitchen | Ice Machine | <1 | Pass | N/A | Testing Complete |
| M20413 | In kitchen by kitchen ie. back wall | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M20416 | In kitchen by kitchen ie. outside wall | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M20417 | In kitchen by kitchen ie. outside wall | Kitchen Sink | <1 | Pass | N/A | Testing Complete |
| M20421 | In kitchen Serving area | Kitchen Sink | 1.4 | Pass | N/A | Testing Complete |
| M20424 | In work room 160B by media center | Classroom Sink | 1.5 | Pass | N/A | Testing Complete |
| M20531 | In office G81 | Classroom Sink | 1.8 | Pass | N/A | Testing Complete |
| M20761 | In hallway hall by 235 LTR 1 of 2 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|---------|---|-------------------|----|------|-----|------------------|
| M26345 | In hallway next to elevator and 261 storage | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M26350 | In hallway 261 between SBR next to 261 and elevator | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08458 | In hallway adjacent to room G15C | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08459 | In hallway adjacent to room G55 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08460 | In Boy's Locker room G57 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08461 | In Girl's locker room G62 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08462 | In hallway adjacent to room G65 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08359 | In hallway adjacent to gymnasium 199 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08360 | In cafeteria adjacent to 170C | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW08361 | In hallway adjacent to room 119C | Drinking Fountain | <1 | Pass | N/A | Testing Complete |



Montgomery County Public Schools Lead in Drinking Water Testing 2018

Executive Summary:

Walter Johnson High School

6400 Rock Spring Drive

Bethesda, Maryland 20814

| | |
|-----------------------------|-----------|
| Date of Test Report: | 3/22/2018 |
| Round of Testing: | Initial |
| # of Outlets Tested: | 51 |
| # of Outlets ≥ 20 ppb: | 0 |
| Low Value (ppb): | <1.0 |
| High Value (ppb): | 7.7 |

Project Status:

Initial testing complete: All results less than 20 ppb.



3/22/2018

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Drinking Water Testing

KCI Job #1214634186

Location: Walter Johnson High School

6400 Rock Spring Drive
Bethesda, Maryland 20814

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of Initial lead in water testing at Walter Johnson High School, located at 6400 Rock Spring Drive in Bethesda, Maryland 20814.

SCOPE OF SERVICES

KCI conducted lead in water testing at Walter Johnson High School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

KCI visited the site on 2/27/2018 and 2/28/2018 to collect samples from 51 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water - Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

There are no results of the lead in water analysis at or above 20 parts per billion (ppb). The lead in water sample results for sample collection date 2/28/2018 are shown in Attachment A.

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM

Attachment:

A- Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: KCI Technologies, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Sample Results for Walter Johnson High School

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB)* | Pass/Fail | Status |
|------------|--------|----------------------|------------------------|----------------|----------------|-----------|------------------|
| LW05322 | | Hallway | Close To Rm 129 | Cooler | <1.0 | Pass | Testing Complete |
| LW05323 | | Hallway | Close To Rm 129 | Cooler | <1.0 | Pass | Testing Complete |
| LW05324 | 128 | Work Room | | Faucet | 2.4 | Pass | Testing Complete |
| LW05325 | 104 | Work Room | | Faucet | <1.0 | Pass | Testing Complete |
| LW05326 | 158 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| LW05327 | 197C | Concession | | Icemaker | <1.0 | Pass | Testing Complete |
| LW05369 | | Kitchen | | Faucet | 3.4 | Pass | Testing Complete |
| LW05370 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW05371 | | Kitchen | | Faucet | 2 | Pass | Testing Complete |
| LW05372 | | Kitchen | | Faucet | 2.8 | Pass | Testing Complete |
| LW05373 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW05374 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW05375 | 170C | Break Room Cafeteria | | Faucet | 1.4 | Pass | Testing Complete |
| LW05376 | | Cafeteria | Next To Rm 170c | Cooler | <1.0 | Pass | Testing Complete |
| LW05377 | 173 | Office Band | | Faucet | <1.0 | Pass | Testing Complete |
| LW05378 | 190B | Concession | Across From Auditorium | Faucet | 7.7 | Pass | Testing Complete |
| LW05380 | 166 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| LW05381 | 154 | Health Room | | Faucet | 1 | Pass | Testing Complete |
| LW05382 | 151 | Work Room Office | | Faucet | 1.9 | Pass | Testing Complete |
| LW05383 | 100 | Office Office | | Faucet | <1.0 | Pass | Testing Complete |
| LW05384 | 155C | Work Room Counselor | | Faucet | 1 | Pass | Testing Complete |
| LW05385 | | Hallway | Next To Gym | Cooler | <1.0 | Pass | Testing Complete |
| LW05386 | 142 | English Office | | Faucet | <1.0 | Pass | Testing Complete |
| LW06462 | G85 | Hallway | Across From | Cooler | <1.0 | Pass | Testing Complete |
| LW06463 | G85 | Hallway | Across From | Cooler | <1.0 | Pass | Testing Complete |
| LW06464 | G65 | Weight Room | Next To | Cooler | <1.0 | Pass | Testing Complete |
| LW06473 | G02 | Home Economics | | Faucet | <1.0 | Pass | Testing Complete |
| LW06474 | G02 | Home Economics | | Faucet | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB)* | Pass/Fail | Status |
|------------|--------|------------------------|---|----------------|----------------|-----------|------------------|
| LW06475 | G02 | Home Economics | | Faucet | <1.0 | Pass | Testing Complete |
| LW06476 | G02 | Home Economics | | Faucet | <1.0 | Pass | Testing Complete |
| LW06477 | G02 | Home Economics | | Faucet | <1.0 | Pass | Testing Complete |
| LW06478 | G02 | Home Economics | | Faucet | 4.7 | Pass | Testing Complete |
| LW06480 | G15C | Hallway | Across From | Cooler | <1.0 | Pass | Testing Complete |
| LW06481 | G15C | Hallway | Across From | Cooler | <1.0 | Pass | Testing Complete |
| LW06482 | G44 | Work Room | | Cooler | <1.0 | Pass | Testing Complete |
| LW06483 | G59 | Training Room | | Faucet | 2.4 | Pass | Testing Complete |
| LW06484 | 244 | Work Room | | Faucet | <1.0 | Pass | Testing Complete |
| LW06485 | 212 | Hallway | Right Of | Cooler | <1.0 | Pass | Testing Complete |
| M07583 | G27 | Work Room | | Faucet | <1.0 | Pass | Testing Complete |
| M07588 | G55 | Hallway | Next to G55 Football Office | Cooler | <1.0 | Pass | Testing Complete |
| M07610 | G65 | Weight Room | Next to G65 Weight Rm | Cooler | <1.0 | Pass | Testing Complete |
| M07612 | | Hallway | Next to Gym | Cooler | <1.0 | Pass | Testing Complete |
| M07619 | 197C | Concession | | Faucet | 2.1 | Pass | Testing Complete |
| M20409 | | Kitchen Kitchen | | Ice Maker | <1.0 | Pass | Testing Complete |
| M20416 | | Kitchen Kitchen | Outside Wall | Faucet | <1.0 | Pass | Testing Complete |
| M20417 | | Kitchen Kitchen | Outside Wall | Faucet | <1.0 | Pass | Testing Complete |
| M20421 | | Kitchen | Serving Area | Faucet | 2.3 | Pass | Testing Complete |
| M20424 | 160B | Work Room Media Center | | Faucet | 1.4 | Pass | Testing Complete |
| M20761 | | Hallway | Hall By 235 LTR 1 of 2 | Cooler | <1.0 | Pass | Testing Complete |
| M26345 | | Hallway | Next to Elevator and Rm 261 Storage | Cooler | <1.0 | Pass | Testing Complete |
| M26350 | 261 | Hallway | Between SBR Next to Rm 261 and Elevator | Cooler | <1.0 | Pass | Testing Complete |

*PPB = parts per billion